

**Foundation for Innovative New Diagnostics India
(FIND India)**

Advertised Tender Enquiry (ATI)

**BID DOCUMENT
FOR**

**SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING OF
SILENT DIESEL GENERATOR (DG) SET AND SERVO CONTROLLED
AUTOMATIC VOLTAGE STABILIZER ACROSS TB LABS UNDER THE
NATIONAL TUBERCULOSIS ELIMINATION PROGRAMME (NTEP)**

Bid Ref. No.: SAMS/FIND India/Proc./Equipment/ATE/04/2022



(Procurement Agency)

STRATEGIC ALLIANCE

Management Services Pvt. Ltd.

Strategic Alliance Management Services Pvt. Ltd,

B-18, Sector-06, NOIDA

Gautam Budh Nagar (U.P.)- 201301

Email: procurement@samsconsult.com

Website: www.samsconsult.com

Section I

NOTICE INVITING BIDS

FOR

SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF SILENT DIESEL GENERATOR (DG) SET AND SERVO CONTROLLED AUTOMATIC VOLTAGE STABILIZER ACROSS TB LABS UNDER THE NATIONAL TUBERCULOSIS ELIMINATION PROGRAMME (NTEP)

Bid Ref. No.: SAMS/FIND India/Proc./Equipment/ATI/4/2022

Dated: 22/10/2022

1. Strategic Alliance Management Services Pvt. Ltd. (SAMS) has been engaged by “Foundation for Innovative New Diagnostics India” (FIND India), New Delhi (a not-for-profit Company created under Section 8 (Indian) Companies Act, 2013) for providing procurement consultancy services for equipment, goods, works and services for TB Laboratories established across India under National Tuberculosis Elimination Programme (NTEP), Ministry of Health and Family Welfare, Govt. of India.
2. SAMS hereby invites **e-bids (through the E-procurement system of FIND India)** from eligible and qualified bidders for the supply of the following Goods, Equipment and related services:

Sch. No.	Description of Goods and Equipment	Total Quantity (Nos.)														
1	Silent Diesel Generator (DG) Set (Supply, Installation, Testing and Commissioning of silent type Diesel generator set of 125 KVA capacity, complete with exhaust piping, earthing all accessories with Automatic Main Failure (AMF) panel including Bypass switch along with Standard Features, spares, accessories and handing it over to the site, thereafter with two years of warranty period)	5														
2	Servo Controlled Automatic Voltage Stabilizer (Supply, installation, testing and commissioning servo controlled Automatic voltage stabilizer of various capacities as mentioned in the Technical Specification along with required cabling work with two years of the warranty period)	51														
<table border="1"><thead><tr><th>The capacity of Voltage stabilizer (VS)</th><th>Bifurcation of total Qty.</th></tr></thead><tbody><tr><td>100 KVA</td><td>18</td></tr><tr><td>120 KVA</td><td>8</td></tr><tr><td>150 KVA</td><td>12</td></tr><tr><td>175 KVA</td><td>11</td></tr><tr><td>60 KVA</td><td>2</td></tr><tr><td>Grand Total</td><td>51</td></tr></tbody></table>			The capacity of Voltage stabilizer (VS)	Bifurcation of total Qty.	100 KVA	18	120 KVA	8	150 KVA	12	175 KVA	11	60 KVA	2	Grand Total	51
The capacity of Voltage stabilizer (VS)	Bifurcation of total Qty.															
100 KVA	18															
120 KVA	8															
150 KVA	12															
175 KVA	11															
60 KVA	2															
Grand Total	51															

3. Bidding will be conducted online through the **E-procurement system of FIND India** by the ‘Advertised Tender Enquiry’ method and procedures as set out in the ‘General Financial Rule – 2017’ and Manual of Policies and Procedure for Purchase of Goods and Works issued by the Department of Expenditure, Ministry of Finance, Govt. of India. **Vendors are requested to submit their proposals online through FIND India E-procurement System only. If not registered yet, kindly go 3. through the attached “USER MANUAL” pdf below the link,**

for the process of vendor registration which will provide the guidance for using this vendor portal and onward submission of the proposal.

Please find below the link for vendor registration

<https://procurementindia.finddx.org/Vendor/VendorRegistration.aspx>



FIND_UserManual_V
endorRegisitation.pdf

4. Bidders are required to submit Bid Security Declaration as per the format provided in the Bid Documents Details are given in Bid Documents
5. The Bid Document can be freely downloaded from the website www.samsconsult.com and E-procurement system of FIND India starting from **10.00 AM on 22/10/2022**. Bidders shall be solely responsible for checking the above website for any addendum/amendment issued subsequent to publication of this IFB and take the same into consideration while preparing and submitting their bids.
6. Bidders' representatives are invited to attend an offline/in-person (physical) **pre-bid meeting at 11.00 AM on 31/10/2022** at the address mentioned above. Please note that non-attendance at the pre-bid meeting will not be the cause of the disqualification of bidders. Bidders can also participate in an online pre-bid meeting through skype link <https://join.skype.com/pK8ho5D4jkFp> at the scheduled time and date of pre-bid meeting. Bidders who are unable to attend the pre-bid meeting (online or offline) can send their written requests for clarification, if any up to 04.00 PM on 30/10/2022 at email procurement@samsconsult.com.
7. **Bids must be submitted online on or before 03:00 PM on 14/11/2022 by Bidders**, registered as Vendor on the e-Procurement System of FIND. All documents required towards submission of bids must be uploaded online.
8. **The Technical Bids will be opened on the same day at 03.30 PM on the e-Procurement System** and the name of bidders who have submitted their bids upto scheduled date and time shall be announced.

Sanjay Rastogi

Director, SAMS

Section-II

Instructions to Bidders

Table of Contents

A. GENERAL	6
1. Introduction	6
2. Language of Bids	6
3. Code of Integrity.....	6
4. Conflict of Interest.....	7
5. Eligible Bidders and Goods	9
6. Bidders' Qualification.....	10
B. BIDDING DOCUMENTS	10
7. Content of Bidding Documents	10
8. Clarifications of Bidding Documents	11
9. Pre-Bid Meeting	11
10. Amendments to Bid Documents.....	11
C. PREPARATION OF BIDS	12
11. Documents Comprising the Bid	12
12. Letter of Technical Bid, Financial Bid and Price Schedule.....	12
13. Alternative Bids	12
14. Bid Prices	12
15. Bid Currency	13
16. Documents establishing the compliance of Goods	13
17. Documents establishing the eligibility and Qualification of the Bidder	13
18. Period of validity of Bids	14
19. Bid Security.....	14
20. Format and Signing of Bids.....	14
D. SUBMISSION AND OPENING OF BIDS	15
21. Submission of Bids	15
22. Deadline for Submission of Bids.....	15
23. Late Bids	16
24. Withdrawal, Substitution and Modification of Bids.....	16
25. Opening of Bids.....	16

E. EVALUATION AND COMPARISON OF BIDS.....	17
26. Confidentiality.....	17
27. Preliminary Examination of Bids.....	17
28. Clarification of Bids.....	17
29. Immaterial Non-conformities in Bids.....	18
30. Determination of Technical Responsiveness.....	18
31. Nonconformities, Errors and Omissions.....	19
32. Qualification of the Bidder.....	19
33. Financial Evaluation and Comparison of Bids.....	19
34. Correction of Arithmetical Errors.....	20
35. Purchaser’s Right to Accept Any Bid, and to Reject Any or All Bids.....	20
F. AWARD OF CONTRACT.....	21
36. Award Criteria.....	21
37. Purchaser’s Right to vary Quantities at the time of Award.....	21
38. Notification of Award.....	21
39. Performance Security.....	21
40. Signing of Contract.....	22

Section – II

Instructions to Bidders

A. GENERAL

1. Introduction

- 1.1 In connection with the Notice Inviting Bids (NIB) for Procurement of Goods, Equipment and related services as **specified in the Section III - Bid Data Sheet (BDS)**, the Purchaser **as specified in the BDS**, has issued these Bidding Documents for the supply of Goods, Equipment and related services **as specified in Section V - Schedule of Requirements**.
- 1.2 This Section provides the relevant information as well as instructions to assist prospective bidders in preparation and submission of bids. It also includes the mode and procedure to be adopted by the Purchaser for receipt and opening as well as scrutiny and evaluation of bids and subsequent placement of award of contract.
- 1.3 Before preparing the bid, and submitting the same to the Purchaser, the bidder should read and examine all the terms & conditions, instructions etc. contained in the Bidding Documents. Failure to provide required information or to comply with the instructions incorporated in this Bidding Documents may result in rejection of bids submitted by bidders.
- 1.4 The bidder shall bear all costs and expenditure incurred and/or to be incurred by it in connection with its bid including preparation, mailing and submission of its bid and subsequently processing the same. The Purchaser shall, in no case be responsible or liable for any such cost, expenditure etc. regardless of the conduct or outcome of the bidding process.

2. Language of Bids

- 2.1 Bid submitted by the bidder and all subsequent correspondences and documents relating to the bid exchanged between the bidder and the Purchaser, shall be written in English language. However, the language of any printed literature furnished by the bidder in connection with its bid may be written in any other language, provided the same is accompanied by a self-certified English translation and, for purposes of interpretation of the bid, the English translation shall prevail.

3. Code of Integrity

- 3.1 The Purchaser and all officers or employees of the purchaser, whether involved in the procurement process or otherwise, or Bidders and their representatives or consultants or service providers participating in a procurement process or other persons involved, directly or indirectly in any way in a procurement process shall maintain an unimpeachable standard of integrity.
- 3.2 The Purchaser and Bidders to uphold the Code of Integrity, which prohibits officers or employees of the Purchaser or a person participating in a procurement process, in respect of the following:
 - (i) any offer, solicitation or acceptance of any bribe, reward or gift or any material benefit, either directly or indirectly, in exchange for an unfair advantage in the procurement process or to otherwise influence the procurement process;

- (ii) any omission, including a misrepresentation that misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (iii) any collusion, bid rigging or anti-competitive behaviour to impair the transparency, fairness and progress of the procurement process;
- (iv) improper use of information shared between the Purchaser and the bidders with an intent to gain unfair advantage in the procurement process or for personal gain;
- (v) any financial or business transactions between the bidder and any officer or employee of the Purchaser, who are directly or indirectly related to tender or execution process of contract;
- (vi) any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (vii) any obstruction of any investigation or audit of a procurement process;
- (viii) making false declaration or providing false information for participation in -
 - a) tender process or to secure a contract;
 - b) disclosure of Conflict of Interest;
 - c) disclosure by the bidder of any previous transgressions with any entity in India or any other country during the last three years or of any debarment by any other Procuring Entity.

3.3 In case of any breach of the Code of Integrity by a bidder or a prospective bidder, the Purchaser after giving a reasonable opportunity of being heard, may take appropriate measures including –

- a) exclusion of the bidder from the procurement process;
- b) calling off of pre-contract negotiations and forfeiture or encashment of bid security;
- c) forfeiture or encashment of any other security or bond relating to procurement;
- d) recovery of payments made by the Purchaser along with interest thereon at bank rate;
- e) cancellation of the relevant contract and recovery of compensation for loss incurred by the Purchaser;
- f) debarment of the bidder from participation in any future procurements of Purchaser for a period not exceeding three years.

4. Conflict of Interest

4.1 Conflict of Interest for the Purchaser or its personnel and bidders is considered to be a situation in which a party has interests that could improperly influence that performance of its duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

- 4.2 Purchaser describes the situations in which a Purchaser or its personnel may be considered to be in Conflict of Interest include, but are not limited to the following -
- a) Conflict of Interest occurs when the private interests of Purchaser or its personnel, such as personal, non-official, extra- professional or other relationships or personal financial assets, interfere or appear to interfere with the proper performance of its professional functions or obligations as a procurement official;
 - b) within the procurement environment, a Conflict of Interest may arise in connection with such private interests as personal investments and assets, political or other social activities and affiliations while in the service of the Purchaser, employment after retirement from service or of relatives or the receipt of a gift that may place the Purchaser or its personnel in a position of obligation;
 - c) Conflict of Interest also includes the use of assets of the Purchaser including human, financial and material assets, or the use of the office of the Purchaser or knowledge gained from official functions for private gain or to prejudice the position of someone the Purchaser or its personnel does not favour;
 - d) Conflict of Interest may also arise in situations where the Purchaser or any of its personnel is seen to benefit directly or indirectly or allow a third party, including family, friends or someone they favour, to benefit directly or indirectly from the decision or action of the Purchaser;
- 4.3 The situations in which bidders participating in a procurement process or their representatives may be considered to be in Conflict of Interest include, but are not limited to the following –
- a) If they or their personnel or representatives or agents have any relationship or financial or business transactions or interests with any official of the Purchaser that are directly or indirectly involved in or related to the procurement process or execution of contract;
 - b) If they receive or have received any direct or indirect subsidy from any other bidder;
 - c) If they have the same legal representative for purposes of the bid;
 - d) If they have a relationship with each other, directly or through common third parties that puts them in a position to have access to information about or influence on the bid of another;
 - e) If they participate in more than one bid in the same bidding process;
 - f) If they have controlling partners in common;
 - g) If a bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the subject matter of procurement of the bidding process or were involved in such preparation in any way;
- 4.4 In the 'Letter of Technical Bid' to be submitted by the bidder, as per format given in **Section VI - Bidding Forms**, all bidders shall provide a signed statement that the bidder is neither associated nor has been associated directly or indirectly with the consultant or any other entity that has prepared the design, specifications and other documents for the subject matter of procurement or is being proposed as Project Manager for the contract;

- 4.5 In case of a holding company having more than one independently manufacturing unit or more than one unit having common business ownership or management, only one unit shall be allowed to submit bid or quote to prevent any Conflict of Interest. Similar restrictions shall apply to closely related sister or subsidiary companies. Such bidders must proactively declare such sister or subsidiary company or common business or management units in similar lines of business;
- 4.6 In cases of agents quoting in offshore procurements on behalf of their principal manufacturers, one agent shall not represent two manufacturers or quote on their behalf in a particular bid enquiry to prevent any Conflict of Interest.

5. Eligible Bidders and Goods

- 5.1 Bidder shall be a private entity, government-owned entity or, any combination of these having a formal intent and legal competency to enter into an agreement or contract and are registered under respective Act and Jurisdiction in India or any other country with which India has not banned trade relations.
- 5.2 Bidder should not have a Conflict of Interest as prescribed and specified in ITB Para 4, which materially affects fair competition.
- 5.3 In addition, any bidder participating in the procurement process shall –
- (i) have fulfilled his obligation to pay such of the tax payable to the Central Government or the State Government or any local authority;
 - (ii) not be insolvent, in receivership, bankrupt or being wound up, not have its affairs administered by a court or a judicial officer, not have its business activities suspended and must not be the subject of legal proceedings for any of the foregoing reasons;
 - (iii) not have, and their directors and officers not have, been convicted of any criminal offence related to their professional conduct or the making of false statements or misrepresentations as to their qualifications to enter into a procurement contract within a period of three years preceding the commencement of the procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
 - (iv) not be debarred by any Procuring Entity under the State / UT Government, the Central Government, Autonomous body, Authority by whatever name called under them, UNOPS, UNDP, SAMS or GFATM as on the date of opening of bids.
- 5.4 All goods to be supplied under the contract shall have their origin in India or any other country with which India has not banned trade relations. The term “origin” used in this clause means the place where the goods are mined, grown, produced, or manufactured or from where the related services are arranged and supplied.
- 5.5 This invitation for bids is open to only Class – I Local Suppliers as per the order Ref. No. P-45021/2/2017-PP (BE-II) dated 16 September, 2020 issued by Department for Promotion of Industry and Internal Trade (DPIIT), Ministry of Commerce and Industry, Govt. of India. A Class-I Local Supplier means a supplier or service provider, whose goods, services or works offered for procurement has local content equal to or more than 50%. The bidder is required to give an undertaking in the Form TECH-1: Form of Bid (Technical) of section -II of the Bid Document to the above effect. If such an undertaking given by a bidder whose bid

¹ <https://dipp.gov.in/sites/default/files/PPP%20MII%20Order%20dated%2016%2009%202020.pdf>

is accepted is found to be false, this would be a ground for immediate termination and further legal action in accordance with law.

5.6 Any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. Where applicable, evidence of valid registration by the Competent Authority shall be attached, failing which their bids shall be rejected. The Competent Authority for the purpose of this clause shall be the Registration Committee constituted by the Department for Promotion of Industry and Internal Trade (DPIIT). More details may be found in the Office Memorandum (O.M.) Ref. F.No.6/18/2019-PPD dated 23/7/2020 issued by Public Procurement Division, Department of Expenditure, Ministry of Finance, Govt. of India. Further, A contractor shall not be allowed to sub-contract works to any contractor from a country which shares a land border with India unless such contractor is registered with the Competent Authority in India. Bidders are required to certify about compliance of above requirement in the Form TECH-1: Form of Bid (Technical) of section -II of the Bid Document to the above effect. If such a certificate given by a bidder whose bid is accepted is found to be false, this would be a ground for immediate termination and further legal action in accordance with law.

5.7 In the 'Letter of Technical Bid' to be submitted by the bidder, as per format given in **Section VI - Bidding Forms**, all bidders shall provide a signed statement that the bidder fulfils the eligibility requirements given in ITB Para 5;

6. Bidders' Qualification

- 6.1 Bidders should substantially meet the qualification criteria as stipulated in the **Section IV - Evaluation and Qualification Criteria**.
- 6.2 Bidders should fill and submit the "Proforma for Performance Statement (for a period of last five years)" provided in **Section VI - Bidding Forms** to provide relevant information and documents in support of fulfilment of bidder's qualification, along with its bid.

B. BIDDING DOCUMENTS

7. Content of Bidding Documents

- 7.1 The Bidding Documents shall include the following Sections, which should be read in conjunction with any Amendment issued in accordance with ITB Para 10.
- Section I Notice Inviting Bids (NIB)
 - Section II Instructions to Bidders (ITB)
 - Section III Bid Data Sheet
 - Section IV Evaluation and Qualification Criteria
 - Section V Schedule of Requirements
 - Section VI Bidding Forms
 - Section VII General Conditions of Contract (GCC)
 - Section VIII Special Conditions of Contract (SCC)
 - Section IX Contract Forms

² <https://www.doe.gov.in/sites/default/files/OM%20dated%2023.07.2020.pdf>

- 7.2 Unless downloaded directly from the Purchaser's website **as specified in the BDS**, Purchaser shall not be responsible for the correctness of the Bidding Documents, responses to requests for clarification, the Minutes of the Pre-bid meeting, if any, or Amendment(s) to the Bidding Documents in accordance with ITB Para 10.
- 7.3 Bidders are expected to examine all instructions, forms, terms, and specifications in the Bidding Documents and to furnish with its Bid all information or documentation as is required by the Bidding Documents.

8. Clarifications of Bidding Documents

- 8.1 A Bidder requiring any clarification of the Bidding Documents shall contact the Purchaser in writing at the Purchaser's address **specified in the BDS**. The Purchaser will respond in writing to any request for clarification, provided that such request is received prior to the deadline for submission of bids as **specified in the BDS**.
- 8.2 The Purchaser shall also promptly publish brief description of the enquiry but without identifying its source and its response at its website as **specified in the BDS**.
- 8.3 Should the clarification result in changes to the essential elements of the Bidding Documents, the Purchaser shall amend the Bidding Documents following the procedure given under ITB Para 10.

9. Pre-Bid Meeting

- 9.1 In order to provide response to any doubt regarding Bidding Documents, or to clarify issues, a pre-bid meeting may be scheduled, **if specified in the BDS**.
- 9.2 During the pre-bid meeting, the clarification sought by representative of prospective bidders shall be responded appropriately. However, they shall be asked to submit their written request by close of business on the next working day. The Purchaser shall publish written response to such requests for clarifications, without identifying its source. In case required, amendment(s), in terms of ITB Para 10 below shall be issued, which shall be binding on all prospective bidders.

10. Amendments to Bid Documents

- 10.1 At any time prior to the deadline for submission of bids, the Purchaser may, pursuant to ITB Para 8 and 9 and for any reason deemed fit, amend or modify the Bidding Documents by issuing Amendment(s).
- 10.2 Such Amendment(s) will be published on Purchaser's website **as specified in the BDS** and the same shall be binding on all prospective Bidders.
- 10.3 In order to give reasonable time to prospective bidders to take necessary action in preparing their bids, the Purchaser may, at its discretion extend the deadline for the submission of bids and other allied time frames, which are linked with that deadline.
- 10.4 Any bidder who has downloaded the Bidding Documents should check the Amendment(s), if any, issued on the Purchaser's website. The Purchaser shall not be responsible in any manner if prospective Bidders miss any Amendment(s) published on Purchaser's website.

C. PREPARATION OF BIDS

11. Documents Comprising the Bid

11.1 The bidder can submit the bid online through the **E-procurement system of FIND India** by using Two Bid System i.e. “**Technical Bid**” and “**Financial Bid**”. The Bid shall comprise the following:

Technical Bid:

- i) Letter of Technical Bid as per Form provided in **Section VI – Bidding Forms**;
- ii) Bid Security declaration furnished in accordance with **ITB Para 19**;
- iii) Bidder Information Form as per Form provided in **Section VI: Bidding Forms**;
- iv) Technical Compliance Sheet as per Form provided in **Section VI: Bidding Forms**;
- v) Documents establishing the compliance of Goods in accordance with **ITB Para 16**;
- vi) Documents establishing bidders' qualification in accordance with **ITB Para 17.2**;
- vii) Manufacturer's Authorization, in case bid is submitted by an Agent, as per Form given in **Section VI: Bidding Forms**;
- viii) Proforma for Performance Statement (for a period of last three years) as per format given in **Section VI: Bidding Forms** along with supporting documents;
- ix) Proforma for other Details of Bidder, Manufacturer and its Bank as per format given in **Section VI: Bidding Forms**;
- x) Bidder firm's Certificate of Incorporation/ Registration, Article and Memorandum of Association or any such registration document;
- xi) Self-attested copy of GSTIN registration;
- xii) Any other document **as required in the BDS**

Financial Bid:

- i) Letter of Financial Bid as per Form provided in **Section VI – Bidding Forms**;
- ii) Price Schedule prepared in accordance with **ITB Para 14**;

12. Letter of Technical Bid, Financial Bid and Price Schedule

12.1 The Letter of Technical Bid, Letter of Financial Bid and Price Schedule shall be prepared as per the Forms furnished in **Section VI: Bidding Forms**. The forms must be completed without any alterations to the text, and no substitutes shall be accepted. All blank spaces shall be filled-in with the information requested.

13. Alternative Bids

13.1 Unless otherwise **specified in the BDS**, alternative bids shall not be considered.

14. Bid Prices

14.1 The prices quoted by the Bidder in the Price Schedule shall conform to the requirements specified below.

14.2 Equipment thereunder must be listed and priced separately in the Price Schedule. The price quoted shall correspond to 100% of the items.

- 14.3 The price to be quoted in the 'Letter of Financial Bid' in accordance with ITB Para 12.1 shall be the total price of the bid.
- 14.4 The price quoted by the Bidder shall be fixed during the Bidder's performance of the Contract and shall not be subject to variation on any account, **unless otherwise specified in the BDS**. The bid submitted with adjustable price quotation shall be treated as nonresponsive and shall be rejected.
- 14.5 The price shall be quoted as specified in the Form of Price Schedule given in **Section VI - Bidding Forms**. The dis-aggregation of price components is required solely for the purpose of facilitating the comparison of bids by the Purchaser. This shall not in any way limit the Purchaser's right to contract on any of the terms offered. Prices shall be entered in the following manner:
- (i) the unit and total price of the Goods on DDP (Delivered Duty Paid) – Consignee Location basis;
 - (ii) the price of related services as specified in Section V - Schedule of Requirements;
 - (iii) Goods and Services Tax (GST) payable on the Goods and related services if the contract is awarded

15. Bid Currency

- 15.1 The bidder should submit its quote in Indian Rupees only.
- 15.2 Bids, where prices are quoted in any other currency shall be treated as non-responsive and rejected.

16. Documents establishing the compliance of Goods

- 16.1 To establish the conformity of the Goods to the Bidding Documents, the Bidder shall furnish as part of its Bid, **Technical Compliance Sheet** as per Form provided in **Section VI: Bidding Forms** and the documentary evidence that the Goods conform to the technical specifications and standards specified in **Section V - Schedule of Requirements**.
- 16.2 The documentary evidence may be in the form of literature, drawings or data, and shall consist of a detailed item by item description of the essential technical and performance characteristics of the Goods, demonstrating substantial responsiveness of the Goods to the technical specification, and if applicable, a statement of deviations and exceptions to the provisions of the **Section V - Schedule of Requirements**.
- 16.3 Standards for workmanship, process, material, and equipment, as well as references to brand names or catalogue numbers specified by the Purchaser in the Schedule of Requirements, are intended to be descriptive only and not restrictive. The Bidder may offer other standards of quality, brand names, and/or catalogue numbers, provided that it demonstrates, to the Purchaser's satisfaction, that the substitutions ensure substantial equivalence or are superior to those specified in the Section V - Schedule of Requirements.

17. Documents establishing the eligibility and Qualification of the Bidder

- 17.1 To establish Bidder's their eligibility in accordance with ITB Para 5, Bidders shall complete the Letter of Technical Bid, included in **Section VI - Bidding Forms**.

- 17.2 The documentary evidence of the Bidder's qualifications to perform the contract if its bid is accepted shall establish to the Purchaser's satisfaction that the Bidder meets each of the qualification criterion specified in **Section IV - Qualification and Evaluation Criteria**.

18. Period of validity of Bids

- 18.1 Bids shall remain valid for the period **specified in the BDS** after the bid submission deadline date prescribed by the Purchaser in accordance with ITB Para 22.1. A bid valid for a shorter period shall be rejected by the Purchaser as non-responsive.
- 18.2 In exceptional circumstances, prior to the expiration of the bid validity period, the Purchaser may request bidders to extend the period of validity of their bids. The request and the responses shall be made in writing. A Bidder may refuse the request without forfeiting its Bid Security. A Bidder granting the request shall not be required or permitted to modify its bid.
- 18.3 The Bidder who agrees to the extension of the period of validity of bids so requested by the Purchaser shall also extend the period of validity of bid securities submitted by them or submit new bid security to cover the extended period of validity of their bids. A bidder whose bid security is not extended or new bid securities not submitted shall be considered to have refused the request to extend the period of validity of its bids and rejected as non-responsive. The decision of the Purchaser will be final and binding in this regard.

19. Bid Security

- 19.1 Bidders shall furnish as part of their bid, a Bid Security Declaration as per the format provided in Section VI – Other Standard Forms
- 19.2 Any bid not accompanied by Bid Security Declaration as specified in ITB Para 17.1 above shall be rejected by the Purchaser as non-responsive.
- 19.3 Bidder will be suspended and declared ineligible for two years from the date of suspension, to submit bids/proposals against Request for Bids / Request for Proposals issued by the Purchaser, in the following cases:
- (a) When the bidder withdraws or modifies its bid during the validity of bids as specified in the Letter of Bid; or
 - (b) when the bidder, having been notified of the acceptance of its bid by the Purchaser during the period of bid validity, (i) fail or refuses to execute the Contract; or (ii) fail to furnish the Performance Security, if required in accordance with the Bid Documents.
- 19.4 The Micro and Small Enterprise (MSE) bidders, registered with MSME or those registered with NSIC are exempted from submission of bid security. In such case, bidder should submit copy of MSME or National small industries corporation (NSIC) registration and documents showing exemption from submission of bid security, in lieu of bid security.

20. Format and Signing of Bids

- 20.1 The Bidder shall submit the online bids as per the instruction provided in the e-procurement portal of FIND India.
- 20.2 The Technical Bid and original of the Financial Bid shall be typed or written in ink with all pages serially numbered and signed by the bidder or a person duly authorized to sign on behalf of the bidder in token

of acceptance of the terms and conditions of the Bidding Documents. This authorization shall consist of a written confirmation **as specified in the BDS** which shall be attached to the Bid.

- 20.3 Any corrections in the bid such as interlineations, erasures, or overwriting shall be valid only if they are duly signed or initialled by the person signing the bid.

D. SUBMISSION AND OPENING OF BIDS

21. Submission of Bids

- 21.1 Bidders has to submit their bids **through FIND India E-procurement System only** (<https://procurementindia.finddx.org/Vendor/VendorRegistration.aspx>). Bidders have to follow the process as specified below:

..

- Register with FIND India E-procurement portal for supplying goods or for providing services.
- Sign up in a secure manner and manage their access password.
- Create and manage profiles online.
- Receive online and email notifications for RFPs for various procurements.
- Submit electronic bids in response to Bid document/RFPs issued by SAMS on behalf of FIND or directly by FIND.

- 21.2 If bidder is not registered yet on FIND India E-procurement system, kindly go through the attached “USER MANUAL” pdf below the link, for the process of vendor registration which will provide the guidance for using this vendor portal and onward submission of the proposal.

- 21.3 **Please find below the link for vendor registration**
<https://procurementindia.finddx.org/Vendor/VendorRegistration.aspx>



FIND_UserManual_V
endorRegistration.pdf

22. Deadline for Submission of Bids

- 22.1 Bids must be submitted online before the given deadline and no later than the date and time **specified in the BDS**.

- 22.2 The date of submission and opening of bids shall not be extended except when –

- a) Adequate number of bids have not been received within the given time and the Purchaser is of the opinion that further bids are likely to be submitted if time is extended; or
- b) the Bidding Documents are required to be substantially modified because of discussions in pre-bid meeting or otherwise and the time for preparations of bids by the prospective bidders appears to be insufficient for which such extension is required.

- 22.3 In cases where the time and date of submission of bids is extended, an amendment to the Bidding Documents shall be issued in accordance with ITB Para 10, in which case all rights and obligations of the Purchaser and Bidders previously subject to the deadline shall thereafter be subject to the deadline extended
- 22.4 If the due date for submission of bids declared as non-working day, the bids shall be received and opened at the same time and hour on the next working day.

23. Late Bids

- 23.1 Bidder will not be able to submit bids online after closing of the deadline (date and time) for the submission of the bid as specified in the BDS.
- 23.2 Manual submission of bid is also not allowed.

24. Withdrawal, Substitution and Modification of Bids

- 24.1 A bidder may substitute, or modify its bid before the deadline for online submission of bids.
- 24.3 No bid shall be withdrawn, substituted, or modified after the time and date fixed for submission of online bids as specified in the BDS.

25. Opening of Bids

- 25.1 The Purchaser will open all bids, online at the time, on the date, and at the place specified in the **Key Bidding information**. The Bidders can view the online bid opening after Login as Vendor using username and password. The name of Bidders shall appear to Bidders attending online bid opening.
- 25.2 The Technical Bid shall be opened at the first instance **at 03.30 PM on 14/11/2022**.
- 25.3 The summary of opening of technical bids shall be generated online and bidders may view the response online on the website.
- 25.4 After the technical evaluation of bids are completed, the Purchaser shall notify those Bidders (through procurement portal itself) whose Bids are found non-responsive at technical evaluation stage, their Financial Bids will not be opened.
- 25.5 The Purchaser shall simultaneously notify in writing those Bidders that have qualified during technical evaluation stage and inform them of the date, time and location for the opening of the Financial Bids. The same information will be updated on the FIND procurement portal also.
- 25.6 The Financial Bids shall be opened online by the Purchaser of those Bidders found qualified during technical evaluation stage. The summary of financial bid opening will be generated online on the procurement portal, which can be viewed by the bidders also after opening and acceptance of the bids by the purchaser.

E. EVALUATION AND COMPARISON OF BIDS

26. Confidentiality

- 26.1 Information relating to the evaluation of bids and recommendation of contract award, shall not be disclosed to bidders or any other persons not officially concerned with the bidding process until information on Contract Award is communicated to all Bidders
- 26.2 Any effort by a Bidder to influence the Purchaser in the evaluation or contract award decisions may result in the rejection of its Bid.
- 26.3 Notwithstanding ITB Para 26.2, from the time of bid opening to the time of Contract Award, if any Bidder wishes to contact the Purchaser on any matter related to the bidding process, it should do so in writing.

27. Preliminary Examination of Bids

- 27.1 The Bid Evaluation Committee constituted by the Purchaser shall conduct a preliminary scrutiny of the opened bids at the beginning to assess the prima-facie responsiveness and record its findings thereof particularly in respect of the following:
- (a) that the bid is signed, as per the requirements listed in the Bidding Documents;
 - (b) that the bid is signed by authorised signatory
 - (c) the bid is valid for the period, specified in the Bidding Documents;
 - (d) that the bid is accompanied by due Bid Security declaration;
 - (e) that the bidder has submitted manufacturer authorization form (in case of bidder is dealer/agent/ non-manufacturer)
 - (f) Bidder agreed to terms and conditions of bid including delivery period
 - (g) that the bid is unconditional and that the bidder has agreed to give the required performance security; and
 - (h) whether any other conditions specified in the Bidding Documents are fulfilled.
 - (i) The Bidder is eligible to supply the goods required under this bid as per basic eligibility specified under ITB para 5 above.
 - (j) The Bidder is categorised as Class – I Local Suppliers as per the order Ref. No. P-45021/2/2017-PP (BE-II) dated 16 September, 2020 issued by Department for Promotion of Industry and Internal Trade (DPIIT), Ministry of Commerce and Industry, Govt. of India. A Class-I Local Supplier means a supplier or service provider, whose goods, services or works offered for procurement has local content equal to or more than 50%. The bidder is required to give an undertaking in the Form TECH-1: Form of Bid (Technical) of section -II of the Bid Document to the above effect.

28. Clarification of Bids

- 28.1 To assist in the examination, evaluation, comparison and qualification of the bids, the Bid Evaluation Committee may, at its discretion, ask any bidder in writing for clarification by a specific date regarding its bid specifically therein that if the bidder does not comply or respond by that date his bid shall be

³ <https://dipp.gov.in/sites/default/files/PPP%20MII%20Order%20dated%2016%2009%202020.pdf>

liable to be rejected. The request of the Committee for clarification and the response of the bidder thereto shall be in writing. Depending on the outcome, such bids shall be ignored or considered further;

- 28.2 Any clarification submitted by a bidder with regard to his bid that is not in response to a request by the Committee specifically shall not be considered;
- 28.3 No change in the prices or substance of the bid shall be sought, offered, or permitted, except to confirm the correction of arithmetic errors discovered by the Committee in the evaluation of the financial bids;
- 28.4 No substantive change to qualification information or to a submission, including changes aimed at making an unqualified bidder, qualified or an unresponsive submission, responsive shall be sought, offered or permitted under any circumstances;
- 28.5 All communication generated as above shall be included in the record of the procurement proceedings.

29. Immaterial Non-conformities in Bids

- 29.1 The Bid Evaluation Committee may waive non-conformities in the bid that do not constitute a material deviation, reservation or omission and deem the bid to be responsive;
- 29.2 The Bid Evaluation Committee may request the bidder to submit necessary information or documents which are historical in nature like audited statements of accounts, GSTIN Registration Certificate, etc. within a reasonable period of time. Failure of the bidder to comply with the request within the given time shall result in the rejection of its bid;
- 29.3 The Bid Evaluation Committee may rectify immaterial non-conformities or omissions on the basis of the information or documentation received from the bidder under ITB Para 29.2.

30. Determination of Technical Responsiveness

- 30.1 The Bid Evaluation Committee constituted by the Purchaser shall determine the responsiveness of a bid to the Bidding Documents based on the contents of the bid submitted by the Bidder;
- 30.2 A bid shall be deemed to be substantially responsive if it meets the requirements of the Bidding Documents without any material deviation, reservation, or omission where: -
 - (a) "deviation" is a departure from the requirements specified in the Bidding Documents;
 - (b) "reservation" is the setting of limiting conditions or withholding from complete acceptance of the requirements specified in the Bidding Documents; and
 - (c) "omission" is the failure to submit part or all of the information or documentation required in the bidding documents.
- 30.3 A "material deviation, reservation, or omission" is one that,
 - (a) If accepted, shall:-
 - (i) effect in any substantial way the scope, quality, or performance of the subject matter of procurement specified in the Bidding Documents; or
 - (ii) limit in any substantial way, inconsistent with the Bidding Documents, the rights of the Purchaser or the obligation of the Bidder under the proposed contract; or
 - (b) if rectified shall unfairly affect the competitive position of other Bidders presenting responsive bids;

- 30.4 The Bid Evaluation Committee shall examine the technical aspects of the bid in particular to confirm that all requirements of Bidding Documents have been met without any material deviation, reservation or omission;
- 30.5 The Bid Evaluation Committee shall regard a bid as responsive if it conforms to all requirements set out in the Bidding Documents, or contains minor deviations that do not materially alter or depart from the characteristics, terms, conditions and other requirements set out in the Bidding Documents, that is, there is no material deviation, or if it contains errors or oversights that can be corrected without any change in the substance of the bid;
- 30.6 Bids that are not responsive or contain any material deviation shall be rejected. Bids declared as non-responsive shall be excluded from any further evaluation.

31. Nonconformities, Errors and Omissions

- 31.1 Provided that a Bid is substantially responsive, the Bid Evaluation Committee may waive any nonconformities in the Bid.
- 31.2 Provided that a bid is substantially responsive, the Purchaser or authorised representative may request that the Bidder submit the necessary information or documentation, within a reasonable period of time, to rectify nonmaterial nonconformities or omissions in the bid related to documentation requirements. Such omission shall not be related to any aspect of the price of the Bid. Failure of the Bidder to comply with the request may result in the rejection of its Bid.
- 31.3 Provided that a bid is substantially responsive, the Bid Evaluation Committee shall rectify quantifiable nonmaterial nonconformities related to the Bid Price. To this effect, the Bid Price shall be adjusted, for comparison purposes only, to reflect the price of a missing or non-conforming item or component.

32. Qualification of the Bidder

- 32.1 The Purchaser shall determine to its satisfaction whether the Bidder meets the qualifying criteria **specified in Section IV - Evaluation and Qualification Criteria**
- 32.2 The determination shall be based upon an examination of the documentary evidence of the Bidder's qualifications submitted by the Bidder, pursuant to ITB Para 17
- 32.3 An affirmative determination shall be a prerequisite for award of the Contract to the Bidder. A negative determination shall result in disqualification of the bid, in which event the Purchaser/ Evaluation Committee shall proceed to the next lowest evaluated bid to make a similar determination of that Bidder's qualifications to perform satisfactorily.

33. Financial Evaluation and Comparison of Bids

- 33.1 In order to evaluate Financial Bids, the Purchaser shall consider the following:
- (a) evaluation will be done for Items, as **specified in the BDS**; and the Bid Price as quoted in accordance with ITB Para 14.
 - (b) price adjustment for correction of arithmetic errors in accordance with ITB 34
 - (c) price adjustment due to quantifiable nonmaterial nonconformities in accordance with ITB 31
 - (d) the additional evaluation factors are specified in **Section IV: Evaluation and Qualification Criteria**

- 33.2 The Purchaser shall compare the evaluated prices of all substantially responsive bids established in accordance with ITB 33 to determine the lowest evaluated bid. The comparison shall be on the basis of DDP (place of final destination) prices, together with prices for any required installation, training, commissioning and other services. The evaluation of a bid will exclude and not take into account IGST / SGST / CGST payable on the Goods and related services if the contract is awarded to the Bidder.
- 33.3 If Bidders are allowed to quote separate prices for different models, the methodology to determine the lowest evaluated price of the Equipment combinations, including any discounts offered in the Letter of Financial Bid Form as specified in BDS and **in Section IV - Evaluation and Qualification Criteria**

34. Correction of Arithmetical Errors

- 34.1 Provided that the Bid is substantially responsive, the Bid Evaluation Committee shall correct arithmetical errors in the following cases, namely:
- (a) If there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Committee there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
 - (b) if there is an error in a calculation of the total corresponding to the addition or subtraction of subtotals, the subtotals shall prevail and the total shall be corrected; and
 - (c) if there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (a) and (b) above.
- 34.2 If the price bid is ambiguous leading to two equally valid total price amounts, the bid shall be treated as non-responsive and rejected.
- 34.3 Bidders shall be requested to accept correction of arithmetical errors. Failure to accept the correction in accordance with ITB Para 34.1, shall result in the rejection of the Bid.

35. Purchaser's Right to Accept Any Bid, and to Reject Any or All Bids

- 35.1 The Employer reserves the right to accept or reject any bid, and to cancel / annul the bidding process and reject all bids at any time prior to contract award, without thereby incurring any liability to the Bidders for which the Purchaser shall keep record of clear and logical reasons properly for any such action / recall of bidding process. In case of cancellation / annulment, all bids submitted and specifically, bid securities, shall be promptly returned to the Bidders.

F. AWARD OF CONTRACT

36. Award Criteria

- 36.1 The Purchaser shall award the Contract to the Bidder whose bid has been accepted after evaluation of bids.
- 36.2 The contract shall not be awarded to more than one bidder by splitting the quantity as given in Schedule of Requirements.

37. Purchaser's Right to vary Quantities at the time of Award

- 37.1 At the time the Contract is awarded, the Purchaser reserves the right to increase or decrease the quantity of Goods and Related Services originally specified in Section IV, Schedule of Requirements, provided this does not exceed the percentages **specified in the BDS**, and without any change in the unit prices or other terms and conditions of the bid and the Bidding Documents.

38. Notification of Award

- 38.1 Prior to the expiration of the period of bid validity, the Purchaser shall notify the successful Bidder, in writing, that its Bid has been accepted. The notification letter (hereinafter and in the Conditions of Contract and Contract Forms called the "Letter of Acceptance") shall specify the sum that the Purchaser will pay the Supplier in consideration of the supply of Goods (hereinafter and in the Conditions of Contract and Contract Forms called "the Contract Price").
- 38.2 Until a formal Contract is prepared and executed, the Letter of Acceptance shall constitute a binding Contract.
- 38.3 The Purchaser shall promptly respond in writing to any unsuccessful Bidder who, after notification of award in accordance with ITB Para 38.1, requests in writing the grounds on which its bid was not selected.

39. Performance Security

- 39.1 Within twenty-eight (28) days of the receipt of Letter of Acceptance from the Purchaser, the successful Bidder, if required, shall furnish the Performance Security in accordance with the GCC, using the Performance Security Form included in **Section IX: Contract Forms**, or another Form acceptable to the Purchaser.
- 39.2 Failure of the successful Bidder to submit the above-mentioned Performance Security or sign the Contract shall constitute sufficient grounds for the annulment of the award and forfeiture of the Bid Security. In that event the Purchaser may award the Contract to the next lowest evaluated Bidder, whose bid is substantially responsive and is determined by the Purchaser to be qualified to perform the Contract satisfactorily.
- 39.3 The validity of the performance security shall be for a period of 45 days beyond the date of completion of all contractual obligations.

40. Signing of Contract

- 40.1 Promptly after notification of Award, the Purchaser shall send the successful Bidder the Contract Agreement
- 40.2 Within twenty-eight (28) days of receipt of the Contract Agreement, the successful Bidder shall sign, date, and return it to the Purchaser

Section III – Bid Data Sheet (BDS)

The following specific data for the goods and related services to be procured shall complement, supplement, or amend the provisions in the Instructions to Bidders (ITB). Whenever there is a conflict, the provisions herein shall prevail over those in ITB

ITB Para Reference	Particulars
	A. General
ITB 1.1	<p>The reference number of the Notice Inviting Bids (NIB) is: SAMS/FIND India/Proc./Equipment/ATI/4/2022</p> <p>The Purchaser is: Strategic Alliance Management Services Pvt. Ltd, B-18, Sector-06, NOIDA Gautam Budh Nagar (U.P.)- 201301</p>
ITB 7.2	http://www.samsconsult.com/FIND.aspx
	B. Bidding Documents
ITB 8.1	<p>The Purchaser's address for the purpose of any clarification is: Strategic Alliance Management Services Pvt. Ltd, B-18, Sector-06, NOIDA Gautam Budh Nagar (U.P.)- 201301</p> <p><i>E-mail: procurement@samsconsult.com</i></p> <p><i>Phone: +91-11-43580 626 / 627</i></p> <p>Requests for clarification should be received by the Purchaser no later than: 04.00 PM 30/10/2022</p>
ITB 8.2	http://www.samsconsult.com/FIND.aspx
ITB 9.1	<p>Pre-Bid Meeting shall be scheduled on hybrid mode (online & offline): Yes</p> <p>The name of contact person, venue, time and date for pre-bid meeting are specified as under:</p> <p>Name of contact person: Mr. Dinesh Kumar, Procurement Manager</p> <p>Contact Details:</p> <p>Phone: 011-43580626/627 (Ext. 105), Mobile: 8800257774;</p> <p>e-mail: kumard@samsconsult.com</p> <p>Address of Venue: Strategic Alliance Management Services Pvt. Ltd, B-18, Sector-06, NOIDA Gautam Budh Nagar (U.P.)- 201301</p>

	Time and Date: 11.00 AM on 31/10/2022 The meeting shall be held online. Prospective bidder may use the link https://join.skype.com/pK8ho5D4jkFp
ITB 10.2	http://www.samsconsult.com/FIND.aspx
C. Preparation of Bids	
ITB 11.1 (xii)	The Bidder shall submit the following additional documents in its Bid: None
ITB 13.1	Alternative Bids shall not be considered.
ITB 14.4	The price quoted by the bidder shall be fixed during the Bidder's performance of the Contract and shall not be subject to variation on any account, except for GST, payable on Goods and related services.
ITB 18.1	The bid validity period shall be 120 days after the deadline for bid submission.
ITB 20.2	The written confirmation of authorization to sign on behalf of the Bidder shall consist of: (1) Copy of Resolution of Board of Directors (2) Authorization Letter issued by Competent authorized on bidder firms letter head / official stationary (3) Notarized affidavit
D. Submission and Opening of Bids	
ITB 22.1	Bidders are requested to submit their bids online through FIND India e-Procurement system. https://procurementindia.finddx.org/Vendor/VendorRegistration.aspx The deadline for Bid Submission is: 03.00 PM on 14/11/2022
ITB 25.1	The Purchaser will open all bids online The date and time for Bid opening is: 03.30 PM on 14/11/2022 https://join.skype.com/ywJ23hyzi7WC
E. Evaluation and Comparison of Bids	
ITB 37.1	The maximum percentage by which quantities may vary is: ±25% (Twenty Five percent)

Section IV – Evaluation and Qualification Criteria

This Section contains all the criteria that the Purchaser shall use to evaluate a bid and qualify the Bidders in accordance with ITB 30 and 32 no other factors, methods or criteria shall be used.

1. Evaluation (ITB 32)

1.1. Evaluation Criteria {ITB 33.1 (e)}

The Purchaser shall use the criteria and methodologies listed in this Section to evaluate Bids. By applying the criteria and methodologies the Purchaser shall determine the Most Advantageous Bid. This is the Bid that meets the Qualification Criteria and has been determined to be:

- a) substantially responsive to the bidding document, and
- b) the lowest evaluated cost. with applicable warranty as specified in the section 3.A. Technical Specifications – General Requirements

The determination of bidder quoting lowest evaluated cost shall be based on the comparison of evaluated bid price carried out on “Delivered Duty Paid (DDP) consignee site basis”, and cost of related services quoted by substantially responsive bidders.

Cost of AMC for 3 years after expiry of warranty period: *such annual prices will also be added for comparison/ranking purpose for evaluation.*

The Purchaser’s evaluation of a Bid to determine lowest evaluated bidder may take into account, in addition to the Bid Price quoted in accordance with ITB 14, using the following factors and methodologies.

2. Qualification of the Bidder (ITB 32)

2.1 Qualification Requirements (ITB 32.1)

After preliminary scrutiny of bids in accordance with ITB Para 27 above, Bidder’s shall be assessed for their qualification for the Schedules quoted by them as per criteria given below:

The Purchaser shall carry out the qualification assessment of the Bidder in accordance with ITB 32, using only the requirements specified. Requirements not included in the text below shall not be used in the evaluation of the Bidder’s qualifications.

a) If the Bidder is a manufacturer:

i) Experience and Technical Capacity

- a) Bidder should be in continuous business of manufacturing / supplying the similar Goods as specified in the bid during last three years prior to bid opening and should have manufactured and supplied the similar Goods (for Sch. I similar goods means DG Set more than 60 KVA and for Sch. II similar means high-capacity voltage stabilizer more than 30 KVA) to the extent of at **least 60% of the quantity** to be procured under this Bid, during last three years preceding the date of opening of bids
- b) To qualify for **each Schedule**, the bidder, should have achieved an average annual turnover during last three financial years (i.e., 2018-19, 2019-20 and 2020-21) as per table below:

Sch. No.	Description of Goods and Equipment	Total Quantity (Nos.)	Average Annual Turnover requirement over last three financial years (2018-19, 2019-20 & 2020-21)
1	Silent Diesel Generator (DG) Set	5	38,00,000
2	Servo Controlled Automatic Voltage Stabilizer (variable capacities)	51	56,00,000

ii) Documentary Evidence

The Bidder shall furnish the following documentary evidence to demonstrate that it fulfills the experience and technical capacity, as above:

- a) Details of past experience in support of qualification requirement given in para a).i).a), including past performance of the Goods offered and on those of similar nature within the past three years, details of current contracts in hand and other commitments (as per form given in **Section VI, Bidding Forms- Performance Statement Form**).
- b) Furnish at least 2 or more documentary evidence (**Client's certificate**) in support of the satisfactory execution including timely supply by the Bidder during last three years. Purchaser may seek feedback from Clients on satisfactory supply of the goods supplied to them. In case, Purchaser gets two or more adverse feedback from existing end users, bids of those bidders will not be consider for further evaluation. In addition, the Purchaser may take technical feedback from Govt. facilities for the use of particular goods offered by the bidder.

b) If Bidder is not manufacturer:

i) Experience and Technical Capacity

- a) If a Bidder is not a manufacturer but is offering the Goods on behalf of the Manufacturer under Manufacturer's Authorization Form (Section VI, Bidding Forms), the Bidder shall demonstrate that it has supplied the similar Goods (for Sch. I similar goods means DG Set more than 60 KVA and for Sch. II similar means high-capacity voltage stabilizer more than 30 KVA) to the extent of at least **40% of the quantity** to be procured under this Bid, during last three years preceding the date of opening of bids.
- b) To qualify for **each Schedule**, the bidder, should have achieved an average annual turnover during last three financial years (i.e., 2018-19, 2019-20 and 2020-21) as per table below:

Sch. No.	Description of Goods and Equipment	Total Quantity (Nos.)	Average Annual Turnover requirement over last three financial years (2018-19, 2019-20 & 2020-21)
1	Silent Diesel Generator (DG) Set	5	38,00,000
2	Servo Controlled Automatic Voltage Stabilizer (variable capacities)	51	56,00,000

ii) Documentary Evidence

The Bidder shall furnish the following documentary evidence to demonstrate that it fulfills the experience and technical capacity, as above:

- a) Details of past experience **of Bidder firm** in support of qualification requirement given in para b).i).b) (applicable for its manufacturer);
 - b) Details of past experience **of manufacturer** in support of qualification requirement given in para b).i). a) (applicable for bidder); including past performance of the Goods offered and on those of similar nature within the past three years, details of current contracts in hand and other commitments (as per form given in **Section VI, Bidding Forms- Performance Statement Form**).
 - c) Furnish at least 2 or more documentary evidence (**Client's certificate**) in support of the satisfactory execution including timely supply by the Bidder during last three years. Purchaser may seek feedback from Clients on satisfactory supply of the goods supplied to them. In case, Purchaser gets two or more adverse feedback from existing end users, bids of those bidders will not be consider for further evaluation. In addition, the Purchaser may take technical feedback from Govt. facilities for the use of particular goods offered by the bidder.
- c) In support of the financial capability/ turnover criteria, bidder should submit Copies of audited financial statements of accounts (including balance sheet, profit and loss account, auditor's reports, and IT returns) certified by the auditor of the Company for last three financial years (i.e., 2018-19, 2019-20 and 2020-21).
- d) Technical demonstration of Goods / Equipment offered:**
- i) Prior to contract award, the lowest evaluated substantially responsive Bidder may be requested to organize demonstration of the goods/ equipment quoted, for inspection of quality and its efficient operation and demonstration of performance parameters before Purchaser or its authorized team. In case, the goods does not perform satisfactorily and does not pass quality / performance test, the bid would be deemed to be non-responsive and Purchaser reserves the right to move to next lowest evaluated responsive bidder for such a technical demonstration of goods.
 - ii) the bidder shall arrange for demonstration of offered goods at desired location intimated later by Purchaser, at own cost, either directly or through authorized Dealer /Distributors, as the case may be, for verification by the Purchaser, whether the goods offered meets the accuracy and other quality parameters as indicated in Technical Specifications at Section IV. The bidder should be prepared to do so by keeping one sample unit of the quoted goods ready at its disposal.

Section V – Schedule of Requirements

A. List of Goods and Equipment required:

Sch. No.	Description of Goods and Equipment	Total Quantity (Nos.)
1	Silent Diesel Generator (DG) Set (Supply, Installation, Testing and Commissioning of silent type Diesel generator set of 125 KVA capacity, complete with exhaust piping, earthing all accessories with Automatic Main Failure (AMF) panel including Bypass switch along with Standard Features, spares, accessories and handing it over to the site, thereafter with two years of warranty period)	5
2	Servo Controlled Automatic Voltage Stabilizer (variable capacities) (Supply, installation, testing and commissioning servo controlled Automatic voltage stabilizer of various capacities as mentioned in the Technical Specification along with required cabling work with two years of the warranty period)	51

Note: Bidders can submit bid for any one or both the items under above Schedules based on their technical capability and qualification criteria specified in the ITB. Bidders are requested to quote for the whole quantity in a schedule. If a bidder quoted for partial quantity in a schedule, the bid will be rejected.

B. List of Related Services:

Sch. No.	Description of Goods and Equipment	Total Quantity (Nos.)	AMC after expiry of 2 years warranty period			
			Type of Service	Year	Year	Year
1	Silent Diesel Generator (DG) Set	5	AMC	Year – 3	Year - 4	Year – 5
2	Servo Controlled Automatic Voltage Stabilizer (variable capacities)	51	AMC	Year – 3	Year - 4	Year – 5

C. Consignee-wise Quantity Distribution:

Sch. 1 : Silent Diesel Generator (DG) Set

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	Designation	Email-Id	Phone No
1	Varanasi, UP	Department Of Microbiology, Institute of Medical Sciences, Banaras Hindu University	Uttar Pradesh	Varanasi	221005	Prof. Shampa Anupurba	HOD microbiology	irlupvrn@mtcp.org	9415396353
2	Rajan Babu Institute of Pulmonary Medicine & Tuberculosis (RBIPMT)	Rajan Babu Institute of Pulmonary Medicine & Tuberculosis (RBIPMT), G.T.B. Nagar, Kingsway camp, Delhi	New Delhi	New Delhi	110009	Dr Vasim Ahmad	Microbiologist	cdstlab.rbipmt@gmail.com	9911231685

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	Designation	Email-Id	Phone No
3	Rajiv Gandhi Institute of Medical Sciences (RGIMS) Adilabad	Department of Microbiology, IP Block, Rajiv Gandhi Institute of Medical Sciences (RGIMS) Adilabad, Telangana	Telangana	Adilabad	504001	Dr Pramod	Microbiologist	Microbiologyrimsadb@gmail.com	8500818181
4	Siddhartha Medical College, Gunadala, Vijayawada	Department of Microbiology, Siddhartha Medical College, Gunadala, Vijayawada, A.P.	Andhra Pradesh	Vijayawada	520002	Dr K Shrikant	Microbiologist	Cdstapvia@gmail.com	9742497779
5	S.P Medical college & Associated Group of Hospitals, Bikaner	S.P Medical college & Associated Group of Hospitals, Bikaner	Rajasthan	Bikaner	334003	Dr BR Bishnoi	lab incharge	drb.29e@gmail.com	9413684655

Sch. 2 : Servo Controlled Automatic Voltage Stabilizer (variable capacities)

Servo Controlled Automatic Voltage Stabilizer (variable capacities)					
Sl. No.	60 KVA	100 KVA	120 KVA	150 KVA	175 KVA
1	Dehradun IRL	Aizawl	Bardhaman GMC	Adilabad RIMS	Ajmer IRL
2	Goa GMC	Aligarh JNMC	KGMU Lucknow	Agartala GMC	Bhopal
3		Bhagalpur	Kolkata IRL	Akola	Gwalior GRMC
4		Cuttack IRL	Madurai MMC	Aurangabad GMC	IRL Indore
5		Gangtok IRL	Nagpur IRL	Bikaner	Jodhpur IRL
6		Guwahati	NDTC Delhi	Dhanbad PMC	KIMS Hubli
7		Hyderabad IRL	Varanasi BHU	Faridkot	LLRMC Meerut
8		Kohima	Vijayawada SMC	Jhansi	NIRTH Jabalpur
9		Kozhikode GMC		Kanpur Nagar	Raichur RIMS
10		Medinipur		Karnal IRL	Raipur IRL
11		Murshidabad		Pawapuri	Shillong
12		Patna IGIMS		RBIPMT Delhi	
13		Raigarh			
14		RMRC Bhubaneswar			
15		Rohtak			
16		Siliguri IRL			
17		Surat GMC			
18		Warangal			
Qty. as per variable capacities (total 51)	2	18	8	12	11

led addresses of all the 51 consignees are mentioned below:

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
1	ALIGARH, UP	Department of Microbiology, JN Medical college, Aligarh Muslim University,	Uttar Pradesh	Aligarh	202002	Mr.Ravi Rajput	-	08285 314780
2	Aurangabad, Maharashtra	Microbiology Department, Government Medical College, Pan Chakki Road,	Maharashtra	Aurangabad	431001	Dr.Jyoti Iravane Bajaj	-	7719901476

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
3	Bhagalpur JLNMCH, Bihar	C& DST Laboratory,RNTCP ,Jawahar Lal Nehru Medical College & Hospital,Mayaganj	Bhagalpur	Bihar	812002	Mr.Prashant		8709770591
4	Bhubaneswar, RMRC, Odisha	Regional Medical Research Centre,Nandankan an Road,ECO Railway Complex,P.O. Chandraasekharpu r,	Orissa	Bhubneshwar	751023	Dr.D.Das		9437920085
5	Cuttack, Odhisa	Anti TB Training and Demonstration Centre,Medical College Campus,	Orissa	Cuttack	753007	Dr Paresh Nath Mohanty		9238579352
6	Dehradun, Uttrakhand	State TB Demonstration and Training Centre,Tyagi Road 107,Chandra Nagar,In front of State Nursing College,	Dehradun	Uttarakhand	248001	Prashant Choudhury		9012342359
7	Guwahati, Assam	State TB Training & Demonstration Centre Intermediate Reference Laboratory Guwahati Medical College 1st Floor Srimanta Sankardeva University of Health Sciences (Campus) N.K. Hill – Top	Assam	Guwahati	781032	Bandana Chaudhury		9864051081
8	Hubli KIMS, Karnataka	TB,Culture & DST Laboratory,ID Ward Building,KIMS Ground,Behind BurnsWard Building, Department of Microbiology,Karna taka Institute of Medical Science. Dharwad District	Karnataka	Hubli	580022	Dr.Kavita		7204491081
9	Hyderabad, TELANGANA	Rajeev Gandhi Institute of Medical Sciences (RIMS), Adilabad	Hyderabad	Telangana	504001	Dr. K. Ashok		9849644591
10	Indore IRL, MP	State TB Demonstration and Training Centre MRTB Hospital/Chest Centre,KEH Compound,	Madhya Pradesh	Indore	452001	Dr Neha Dawar		7697332709
11	Jabalpur NIRTH, MP	National Institute for Research in tribal Health (NIRTH),Microbiolo gy Division,NIRTH (ICMR) Campus,Nagpur Road,Garha,	Madhya Pradesh	Jabalpur	482003	Dr. Jyothi Bhat		9926315005

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
12	Karnal, Haryana	Haryana Govt.Public Health Laboratories Civil Hospital	Haryana	Karnal	132001	Dr. Ravi		7988772565
13	Kolkata West Bengal	State TB Centre & Demonstration Centre, 2nd floor, B.C. Roy PGIPS (Annexe Building), 38 Badan ray Lane Belehata,	West Bengal	Kolkatta	700010	Dr. Prashant		7980596795
14	Lucknow, UP	CSM Medical University (KGMC), Department of Microbiology, Shah meena Road,	Uttar Pradesh	Lucknow	226003	Dr.Amita Jain		9415023928
15	Nagpur, Maharashtra	State TB Demonstration and Training Centre, Govt. Medical College, Ajni Road, Nagpur, Maharastra	Maharashtra	Nagpur	440003	Mr Tanvir Khan		9422120290
16	New Delhi, NDTBC	New Delhi TB Centre, Near Delhi Gate, Jawaharlal Nehru Marg,	New Delhi	New Delhi	110002	Dr Kaushal		9899371930
17	Raichur, RIMS, Karnataka	Raichur Institute of Medical Sciences (RIMS), Hyderabad Road	Karnataka	Raichur	584101	Dr. B.V Peerapur		9448139438
18	Raipur IRL, Chhattisgarh	State TB Training & Demonstration Centre, Regional Leprosy Training and Research Institute Campus, Opp. MMI Hospital,	Chhattisgarh	Raipur	492015.	Dr Sachin Chandraker		9827683212
19	Siliguri, NBMC, West Bengal	Culture & DST Laboratory, (Dept. of Microbiology), North Bengal Medical College, Govt. of West Bengal, Sushrutana gar	West Bengal	Silliguri	734012	Dr. Champa Chakraverty		9434019868
20	Varanasi, UP	Department Of Microbiology, Institute of Medical Sciences, Banaras Hindu University	Uttar Pradesh	Varanasi	221005	Prof. Shampa Anupurba		9415396353
21	Ajmer, Rajasthan	Kamala Nehru State TB Demonstration and Training Centre, Near Soochana Kendra, In Front of Church, Jaipur Road,	Rajasthan	Ajmer	305001	Dr. TarunPatni		9461904433
22	Jodhpur SNMC, Rajasthan	Kamla Nehru Chest Hospital, Of Dr S N Medical College, LPA Lab,	Rajasthan	Jodhpur	342008	Mr. Naseer Khan		9314443777

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
		Infectious Disease Institute, Pal Link Road,						
23	Madurai, Tamil Nadu	Madurai Medical College, Microbiology Department, Panagal Park Road, Near Anna Bus Stop,	TamilNadu	Madurai	625020	Mr. Roban		8870083206
24	GRMC, Gwalior	Gajra Raja Medical College, Department of Microbiology	Madhya Pradesh	Gwalior	474009	Dr K.P. Ranjan		9009021907
25	IRL Gangtok, Sikkim	IRL-TB Lab, Annexure building I, Near Ayush, New STNM Hospital, Sochakgang,	Sikkim	Gangtok	737101	Dr.Karma Doma Bhutia		6295326414
26	IRL Agartala, Tripura	Agartala Govt. Medical College, TB Laboratory, Department of Microbiology, PO - Kunjaban,	Tripura	Agartala	799006	Dr. Tapan Majumdar		. 8837349643
27	IRL Goa	Goa Medical College, Department of Microbiology,	Goa	Bambolim	403202	Dr. Savio Rodrigues		9422389736
28	IGIMS Patna, Bihar	Department of Microbiology, Indira Gandhi Institute of Medical Sciences, Sheikhpur, Patna, Bihar	Bihar	Patna	800014	Dr Rakesh Kumar	igims.mdrtb@gmail.com	9471665710
29	Burdwan Medical College, Baburbag, Burdwan	Burdwan Medical College, Baburbag, Burdwan, West Bengal	West Bengal	Burdwan	713104	Dr Atasi Maji (Biswas)	cdstwbpdn@gmail.com	
30	Govt Medical College, Kozhikode	Department of Microbiology, Govt Medical College, Kozhikode, Kerala	Kerala	Kozhikode	673008	Dr Beena Philomina	clinicalmicrocalicut@gmail.com	9446161949
31	IRL-TB, Department of Microbiology, Government Medical College	IRL-TB, Department of Microbiology, Government Medical College, Majura Gate, Surat, Gujarat	Gujarat	Surat	395001	Dr Vibhuti Patel	irlqusrtrmtcp.org	9427780407
32	Patliputra Medical College, Dhanbad	Patliputra Medical College, Dhanbad, Jharkhand	Jharkhand	Dhanbad	826001	Ms Sandhya	cdstdhanbad@rmtcp.org	9128466088
33	Rajan Babu Institute of Pulmonary Medicine & Tuberculosis (RBIPMT)	Rajan Babu Institute of Pulmonary Medicine & Tuberculosis (RBIPMT), G.T.B. Nagar, Kingsway camp, Delhi	New Delhi	New Delhi	110009	Dr Vasim Ahmad	cdstlab.rbipmt@gmail.com	9911231685
34	Rajiv Gandhi Institute of Medical Sciences (RGIMS) Adilabad	Department of Microbiology, IP Block, Rajiv Gandhi Institute of Medical Sciences (RGIMS) Adilabad, Telangana	Telangana	Adilabad	504001	Dr Pramod	Microbiologyrimadb@gmail.com	8500818181

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
35	Siddhartha Medical College, Gunadala, Vijayawada	Department of Microbiology, Siddhartha Medical College, Gunadala, Vijayawada, A.P.	Andhra Pradesh	Vijayawada	520002	Dr K Shrikant	Cdstapvia@gmail.com	9742497779
36	LLRM Medical College, Garh Road, Meerut	Department of Microbiology, LLRM Medical College, Garh Road, Meerut, Uttar Pradesh	Uttar Pradesh	Meerut	250004	Dr. Amit Garg	amitdrgarg@rediffmail.com	9412802533
37	S.P Medical college & Associated Group of Hospitals, Bikaner	S.P Medical college & Associated Group of Hospitals, Bikaner	Rajasthan	Bikaner	334003	Dr BR Bishnoi	drb.29e@gmail.com	9413684655
38	STDC IRL-Bhopal	STDC IRL-Bhopal, State TB Hospital Campus, Idgah Hills, Bhopal-462001 Bhopal. Madhya Pradesh.	Madhya Pradesh	Bhopal	462001	Dr. Soumya Dhawa	lrmpbpl@rntcp.org	9669531250
39	Murshidabad Medical College and Hospital	Murshidabad Medical College and Hospital, Station Road, Berhampore, Murshidabad, West Bengal	West Bengal	Murshidabad	742 101	Dr Sangeeta Saha	Sangita.stm@gmail.com	9476176266
40	DR-TB Centre Falkawn, MIMER Medical College Campus, Aizwal	DR-TB Centre Falkawn, MIMER Medical College Campus, Aizwal, Mizoram	Mizoram	Aizwal	796004	Dr. Zothankhuma Chhakchhuak	dtomzaw@rntcp.org	7085890576
41	Government Medical College, Akola	Government Medical College, Department of Microbiology, 2nd Floor, Collector office road, Near Ashok watika, Akola	Maharashtra	Akola	444001	Dr Nitin Ambhore	naambhore@rediffmail.com	9822698540/9850621354
42	Pandit B D Sharma Post Graduate Institute of Medical Sciences (PGIMS)	Pandit B D Sharma Post Graduate Institute of Medical Sciences (PGIMS) Rohtak, Haryana	Haryana	Rohtak	124001	Dr Aparna, HoD	Aparnaparmar2008@rediffmail.com	9896354269
43	Guru Gobind Singh Medical College, Faridkot	Guru Gobind Singh Medical College, Sadiq road, Faridkot Punjab	Punjab	Faridkot	151204	Dr. Vishal Sharma	vsgmcs@gmail.com	9501323322
44	Vardhman Institute of Medical Sciences, Pawapuri	Vardhman Institute of Medical Sciences, Pawapuri, Nalanda, Bihar	Bihar	Pawapuri	803115	Dr Gyan Bhushan	superintendentvims.pawapuri@gmail.com	8521831415/9470003131
45	Kakatiya Medical College, Warangal	Kakatiya Medical College, Warangal, Rangampet Street, Warangal 506007, Telangana, India	Telangana	Warangal	506007	Dr Sridevi	sreedevikonda143@gmail.com	9848409171
46	Late Sri Lakhiram Agarwal Memorial Government Medical College, Raigarh	Late Sri Lakhiram Agarwal Memorial Government Medical College, Raigarh, Chhattisgarh	Chhattisgarh	Raigarh	496001	Dr Aruniti	Microbiologygmcragarh@gmail.com	9425237225

Sl. No.	Consignee Name	Address	State	City	Pin Code	Contact Name	E-mail Id	Phone No
47	Ganesh Shankar Vidyarathi Medical College, Kanpur Nagar	Ganesh Shankar Vidyarathi Medical College, Kanpur Nagar, Swaroop Nagar, Kanpur	Uttar Pradesh	Kanpur	208002	Dr. Madhu Agarwal	madhudec07@gmail.com	941542152
48	Maharani Laxmibai Medical College, Jhansi	Maharani Laxmibai Medical College, Jhansi- Kanpur Road, Bundelkhand University, Jhansi, Uttar Pradesh	Uttar Pradesh	Jhansi	284001	Dr. Namita Agarwal	cdstjhansiup@gmail.com namita.srivastava.singh@gmail.com	8171203753
49	State TB Cell, Reid Provincial Hospital, Shillong	State TB Cell, Reid Provincial Hospital , Shillong, , Meghalaya,	Meghalaya	Shillong	793002	Dr. J. Lakiang	stomg@rntcp.org	8014067629
50	Naga Hospital Authority, Kohima	Naga Hospital Authority, Kohima, Nagaland	Nagaland	Kohima	797001	Dr. Margaret Yhome	dtongkma@rntcp.org	9436420966
51	Midnapur Medical College ,Vidya sagar Road	Midnapur Medical College ,Vidya sagar Road, PO- Midnapur, Ps- Kotwali, Dist.- Paschim Medinipur	West Bengal	Midnapore	721101	Dr.(Prof.)Partha SarathiSatpathi		9474679186

D. Delivery & Completion Schedule:

Sch. 1- Silent Diesel Generator (DG) Set

The delivery shall be made within **120 days** (90 days for delivery and 30 days for installation) from the date of issue of the Notification of Award (NOA). Delivery Order.

Sch. 2 : Servo Controlled Automatic Voltage Stabilizer (variable capacities)

The delivery shall be made within **165 days** (120 days for delivery and 45 days for installation) from the date of issue of the Notification of Award (NOA). Delivery Order.

3. Technical Specifications

Sch. 1 Diesel Generator (DG) set specifications

Scope of work: Supply, Installation, Testing and Commissioning of silent type Diesel generator set of about **125 KVA** capacity, complete with exhaust piping, earthing all accessories with Automatic Main Failure (AMF) panel including Bypass switch along with Standard Features, spares, accessories and handing it over to the site, thereafter.

D.G Set shall comprise of: -

a) Engine: -

Four stroke cycle (air cooled up to 15 KVA and water cooled above 20 KVA), electric start, developing required brake horsepower (BHP) at 1500 revolution per minute (RPM) under continuous duty conditions. The engine shall be designed to run continuously, conforming to BS: 5514/ DIN-6271/IS 10001/IS 10002/ ISO – 3046. with an overload capacity of 10% for one hour in any 12 hours continuous under standard reference conditions. The diesel engine model shall be tested & certified for complying with CPCB (Central Pollution Control Board) norms. The engine shall be complete with standard accessories, spares and tools as detailed below: -

- i. Radiator with fan
- ii. Exhaust gas turbocharger
- iii. Residential type silencer with required length of exhaust pipe
- iv. Air cleaner
- v. Fuel lift pump
- vi. Lube oil filter
- vii. Fuel filter
- viii. Heavy Duty dynamically balanced flywheel
- ix. Electronic governor
- x. Starter with suitable capacity battery
- xi. Battery charging unit of suitable capacity for equipment
- xii. Microprocessor based DG set control panel:
 - o consisting of engine safety module with built in ON/OFF/Start key, emergency stop, Lube oil pressure switch gauge, battery charging voltmeter, hour meter, coolant temperature gauge controller.
 - o Alarms & indications: Low Lube oil pressure, high coolant temperature, low coolant temperature, weak battery warning, sensor failure indication, over speed shut down system etc.

b) Alternator: -

The alternator shall be rated capacity at 0.8 power factor, 415 volts, 3 phase, 4 wire, 50 cycles/sec, 1500 rpm, self-excited and self-regulated, with brush less excitation. Band of voltage regulation shall be +2.5% of rated voltage from no load to full load. Insulation class shall be "H" for temperature rise consideration. The alternator shall be designed to withstand tropical/Indian geographical conditions. Required output shall be under NTP (Normal Temperature and Pressure) conditions. The alternator shall comply with BS 2613/IS 4722/IEC 34, latest edition.

c) Base Frame & Mounting Arrangement: -

The engine and the alternator shall be directly coupled to each other by means of couplings to form compact arrangement. Cooling system, engine and alternator units need to be mounted on a rigid fabricated Mild Steel common base frame. The base frame of the diesel generating set must be sturdy and fabricated/ welded

construction out of Mild Steel channel iron base of suitable size for mounting the above the engine and alternator. The base frame must be suitably designed to simplify the transportation, handling, slinging, erecting, and commissioning. The base frame must be painted with anti-corrosive epoxy painting. A set of anti-vibration pads must be provided between base frame and engine alternator.

d) Battery: -

Suitable shield maintenance free (SMF) batteries of standard make with leads and terminals shall be part of the equipment. The pack must be suitably positioned and to be easy withdrawal for the service. The battery pack must be minimum 180 AH.

e) Fuel Tank: -

Fuel Tank must be located nearest to the DG set enclosure and ensure the diesel free flow. Suitable capacity of fuel tank needs to run the DG set for about minimum of 12 hours. The fuel tank must consist of mounting bracket, level indicator, fuel inlet, fuel outlet, air vent, drain plug, inlet arrangement for direct filling and set of hoses for inlet and return.

Fuel consumption: $\frac{1}{4}$ th of the total KVA rating or better on 100 % (full) load.

f) Exhaust Piping: -

The exhaust piping shall be of suitable size and dimensions as per manufacturers recommendations meeting the hospital standards and need to be customized as per the site requirements. The residential silencer must be provided to minimize the noise level with hospital setup conditions. The exhaust piping must be insulated with heat resistant material (asbestos and/ glass wool) and clamped/supported, mounted on the wall/ floor with suitable size clamp. Outlet of exhaust shall be taken out from the structure as per site conditions and covered to protect from atmosphere effects like rain etc. The exhaust piping must be plastered after completion of all the work. The material of piping shall be of approved make and quality of Mild Steel with necessary bends and flanges (for indoor installations).

g) Acoustic Enclosure:

The enclosure must be CPCB (Central Pollution Control Board) approved with soundproof enclosure. The enclosure must be modular construction with hinge bolted structure to provide easy dismantling and reassembling. The DG set with enclosure shall undergo strict quality checks and testing to achieve high-end performance so that the offered DG set with enclosure enables the sound reduction and thus as per latest CPCB norms of noise at 1 Mtr. distance under free condition should be 75 db.

The Acoustic enclosure should be incorporated following:

- (i) The base plate fabricated with sheet metal of suitable thickness.
- (ii) The roof, sidewalls, integral partition, and doors shall be sandwich design made from good quality CRCA (cold rolled close annealed) sheet steel.
- (iii) The Acoustic enclosure shall be naturally cooled to maintain approximate temperature difference with ambient air of 70 deg C and if required forced ventilation shall also be considered.
- (iv) The sound absorption material is selected from either glass wool/PU foam/ PVC foam of relevant thickness and density to have higher sound absorbing coefficient with low thermal conductivity to meet the performance.
- (v) The enclosure construction shall provide sufficient access for maintenance work. The door handles should be lockable type.

(vi) The control panel must be suitably mounted inside the DG set enclosure and enclosure door is provided with panel viewing window made from glass/ Acrylic and sealed with high quality Rubber gasket.

(vii) The enclosure shall be complete with:

- Arrangement for power cable connection for load and mains supply
- Integral- Residential Exhaust Silencer
- Suction Louvers
- Discharge Louvers
- Open able & lockable doors with airtight, high quality rubber gasket
- Interior lighting arrangement with ON/OFF switch on control panel as per the DG set size & Lifting arrangement
- The engine and alternator must be flexibly coupled, aligned, and mounted with suitable anti vibration mountings.

h) Installation of D.G. Set: -

R.C.C. Foundation: The D.G. set shall be installed on suitable R.C.C. foundation after preparing the excavation pit, R.C.C. foundation bed etc. of requisite size, length and dimensions shall be provided. The quantity of R.C.C. material shall be as per manufacturer's design.

Erection of D.G. set: The base frame on which the engine and the alternator are mounted shall be tightened to rag bolts if required with proper levelling and alignment. The supplier needs to fill the diesel tank full on installation and initial battery charging, onsite fuel consumption testing, load trial, transportation and unloading of DG set.

Automatic Main Failure (AMF) control Panel with bypass / change over switch

Automatic start of 60 KVA/125 KVA/160 KVA Generator sets on main supply electrical failure without requiring any human intervention. Similarly on restoration of mains supply it shall be able to transfer the load to mains supply and switch off the Generator set automatically (auto on and off). The Control panel shall be designed for automatic on mains failure' operation of the generator set. The panel must be in built design (inside acoustic enclosure) cubicle pattern and fabricated out of 16 SWG. Mild steel Sheet treated with anti-corrosion and painted with two coats of approved quality shade synthetic enamel / Power coated paint and appropriate ventilating arrangement. AMF should be ideally located near by the Low tension (LT) distribution panel of the laboratory.

The panel shall be complete with the following:

- i. Molded Case Circuit Breaker (MCCB) suitably rated with standard accessories.
- ii. Contactor of suitable rating.
- iii. Neutral isolation contactor of suitable relays.
- iv. Set of control fuses and auxiliary relays.
- v. Set of tinned Copper busbars of suitable rating.
- vi. Automatic battery charger circuit having variable input voltage from 180-230V but the constant output DC voltage, with ON/OFF switch, with ON indication, reverse polarity indication, DC battery charging ammeter.
- vii. Engine on-off (push button type).
- viii. Microprocessor based AMF logic controller with following features:

- (1) 3 Phase sensing of mains failure
 - (2) Impulse start of DG Set
 - (3) Off/Manual/Auto/Test selector switch
 - (4) Sensing of mains voltage presence
 - (5) Engine idling/cooling
 - (6) Mains metering on one common screen (three phase) by providing load manager
 - (7) Digital Voltmeter
 - (8) Digital Ammeter
 - (9) Digital Frequency
 - (10) Digital KW meter
 - (11) Digital Power Factor meter
 - (12) Digital KWh meter
- ix. All other electrical/electronic components required for the functioning of the AMF control panel as per manufacturer's design/guidelines.

Indications/alarm

- Five number- indicating lamps to indicate mains low voltage, load on mains, set running, load on set and battery charger on.
- Audio visual alarm for low liberating oil pressure, high water temperature, high cylinder head temperature, start failure and DG overload.
- Common alarm for engine failure
- Set of Red Yellow Blue (RYB) indicating lamps for generator supply

The components used in the fabrication of the panel shall be of standard quality/ reliability and shall be of reputed make, the spares of which are readily available in the local market.

Earthing:

suitable earthing arrangement will be provided. Four number of earth sets for DG set as below:

- GI Plate earthing (2 sets) body earthing
- Copper earthing (2 sets) neutral earthing

Documentation:

- 1 set of following documents shall be provided with each set: -
 - Test Certificate of diesel engine.
 - Test certificate of Alternator.
 - Test Certificate of D.G. Set.
- One set of operating manuals and two sets of control circuit drawing of panel in laminated form for the record purpose shall be provided.
- The standard diagrams (Electrical & Electronics) and documents must be supplied along with the D. G. Set.

Painting:

All equipment shall be suitably cleaned, painted, and protected against corrosion and damage.

Training:

Training should be provided to the site personals on D. G. Set operations and maintenance at the time of installation.

Warranty:

- All the equipment shall be guaranteed against unsatisfactory performance and/ or break down due to defective design, workmanship, or material for a period of **two years** from the date of commissioning at the site. The equipment or components or any part thereof or consumable items like (lube oil, all filters etc.), so found defective/required for routine replacement during the guarantee/ warranty period shall be forthwith repaired or replaced free of cost to the entire satisfaction of the site.

-Supplier to arrange periodic preventive maintenance and breakdown service visit during the two years of warranty period.

- First preventive maintenance is at 50 hours or 1 month from the date of commissioning, whichever occurs first, the first preventive maintenance is very important and mandatory, to be execute with zero tolerance.
- Next Preventive maintenance is to be done at every 300 Hours or half yearly from the date of commissioning, whichever occurs first with replacement of consumables / any part of DG set.
- Subsequent Preventive maintenance is to be done at every 600 Hours or 1 year from the date of commissioning, whichever occurs first with replacement of consumables / any part of DG set.
- Service call to be attended as and when required within 24 -48 hrs. of time.
- Any additional service visit as per manufacturer standards or recommendation.

Maintenance: Works need to be covered during AMC period (after completion of the two-year of warranty period):

I. Mechanical work (monthly basis):

- a. Checking the engine for its smooth running, unusual noise and colour of the smoke from the exhaust.
- b. Checking and adjusting fan belt tensions. Changing of the same if required.
- c. Cleaning of the Air filters to increase their life as well as proper inflow of air and replace if required.
- d. Checking for conditioning of coolant level and refill if required.
- e. Checking for conditioning of lube oil level and refill if required.
- f. Carrying out valve tappet setting as and when required.
- g. Checking of mounting bolts and replace if required.
- h. Checking for the proper functioning of engine safety like high water temperature gauge, oil pressure gauge, oil temperature gauge etc.
- i. Checking of turbo charger and accessory drive whenever required
- j. Checking the alignment of engine and alternator.
- k. Checking of proper functioning of instrument panel and AMF panel.
- l. Greasing of alternator bearing as per manufacturer recommendation.
- m. Fuel system
 - Checking and maintenance of fuel system including fuel tank, fuel piping, fuel valve etc.
 - Any leakage from the fuel line system to be repaired.
- n. Exhaust system
 - Checking and maintaince of exhaust silence and exhaust stack etc.
 - Any smoke leakage from the exhaust system to be repaired.
 - Checking of insulation of exhaust piping.
- o. Carry out any other periodic maintaince check as per OEM checklist.

II. Electrical work (monthly basis):

- a. Checking and fault finding associated with the electrical systems of the engine.

- b. General cleaning of alternator of the DG set.
- c. Cleaning of battery terminals & de-sulphation and checking its functionality.
- d. Checking of wiring system for any loose and resolving it.
- e. Maintenance for smooth functioning if different parameters in generator engine and AMF panel.
- f. Diagnosis of various electrical faults and rectification at site.
- g. Fault rectification of AMF panel along with accessories.
- h. Maintenance of earth resistance and measuring of earth resistance on quarterly basis.

III. A proper Logbook for Service Record must be maintained.

IV. Material / spares which are not covered under standard AMC, will be in the scope of user/ client side.

Location of DG set and AMF panel of all the five sites are mentioned below:

1. Varanasi site

Location of DG set (Ground Floor)



Location of AMF panel (at Ground floor near to the existing distribution panel & servo stabilizer):



2. RBIPMT, Delhi

Location of DG set (Ground Floor)



Location of AMF panel (at Ground floor near to the proposed DG set area)




3. RIMS, Adilabad

Location of DG set (Ground Floor, Open space near to old TB Ward)



Location of AMF panel (at Ground floor near to the existing LT panel):



Existing Cable distribution at RIMS Adilabad



Note: Extra civil work required for the removal and fixing of these slabs.

4. SMC Vijayawada:

Location of DG set (Ground Floor, Open space)



Location of AMF panel (at Ground floor near to the existing distribution LT panel):



5. SPMC Bikaner

Location for DG Set (at Ground Floor)



Location for AMF Panel (at First floor):



Sch. 2 Servo Controlled Automatic Voltage Stabilizer

Generic

- **Servo Controlled Automatic Voltage Stabilizer**
- **Capacity rating: 175 KVA/ 150 KVA/ 120 KVA/ 100KVA/ 60 KVA**
- **No of phase: Three phase**

Constructional

- Control type: Digital Microcontroller based
- Input voltage ranges: 170-280V AC phase voltage, (3 phase: 340-490 V) 50 HZ
- Output voltage ranges: 415 V \pm 1 % (adjustable between 390 V-420 V) AC
- Type of cooling: Oil cooled (including first filling of cooling oil)
- Transformer (s) winding material: copper
- Indicator: Input & output voltmeter and ampere meter should be separate for each three phases. All meters should be digital only.
 - a. Input phase to neutral
 - b. Input phase to phase
 - c. Output phase to neutral
 - d. Output phase to phase
 - e. Load current in all three phases
 - f. Frequency
- Manual bypass switch shall be provided in case any breakdown we can bypass incoming raw power
- Suitable rated Miniature Circuit Breaker (MCB) shall be provided
- Size:
 - 175 KVA: approx. 6' x 4' x 4'6" (L X W XH)
 - 150/120/100 KVA: approx. 5' x 4' x 4' (L X W XH)
 - 60 KVA: approx. 4' x 3' x 4' (L X W XH)
- Enclosure: Mild steel cabinet with powder coating
- Environment: Indoor continuous operation
- Mounting: on wheels
- Input and output cable terminals: suitable heavy-duty copper/ brass connectors shall be provided for connection
- Earth terminal: suitable terminal stud shall be provided
- System construction as per IS 9815.

Functional

- Compatible to Generator supply
- Efficiency: above 98 %
- Power factor: minimum of 0.8
- Continuous duty: yes (100%)
- Effect on Load power factor: NIL
- Waveform Distortion: NIL
- Connection: star
- Operating frequency: 50 HZ
- Trip and restart: Auto system
- Reset: Manual/ auto reset with time delay

- System: both balanced and unbalanced 4 wire Red Blue Yellow Neutral (R B Y N)
- Response time: less than 100 milli second
- Correction speed: Approx. 70 V/sec or better
- Overload capacity: 120 %
- Insulation: minimum Class B
- Operating temperature: 0- 45 deg C
- Provisioning of cabling: Input and output terminals with provision for fixing cable glands (cable requirement will vary for site to site)

Protection

- Electronic over and under voltage trip with time delay
- Electronic overload protection
- Single phase prevention protection and cutoff
- Phase reversal protection and cutoff
- Audio visual alarm is required for tripping conditions

Certification

- The manufacturer must have a management system certified to ISO 9001. Quality and safety standards met by the product to be listed.
- The Voltage stabilizer should have Conformité Européenne (CE) or IS 9815.

Warranty

The manufacturer / bidder should provide standard two-years of warranty and comprehensive maintenance services (CMC) and should be able to provide Annual Maintenance Contract (AMC) after completion of warranty period.

Installation & Commissioning

The manufacturer / bidder should arrange onsite installation and commissioning of Voltage stabilizer in coordination with the local electrical/Public Work Department (PWD) engineer/ site in charge.

Section VI – Bidding Forms

Letter of Technical Bid

The Bidder must prepare the Letter of Technical Bid on its letterhead clearly showing the Bidder's complete name and address.

Note: All italicized text is for use in preparing these forms and shall be deleted from the final products.

Date: **[insert date (as day, month and year) of Bid Submission]**

Bid Ref. No.: **[insert number of bidding process]**

To: **[insert complete name of Purchaser]**

- (a) We have examined and have no reservations to the Bidding Documents, including Addenda issued in accordance with Instructions to Bidders (ITB 10);
- (b) We meet the eligibility requirements and have no Conflict of Interest in accordance with ITB 4;
- (c) We offer to supply in conformity with the Bidding Documents and in accordance with the Delivery Schedules specified in the Schedule of Requirements the following Goods: **[insert table giving brief description of the Goods, Equipment and Related Services]**;
- (d) Our bid shall be valid for a period fixed for the bid submission deadline in accordance with the Bidding Documents, and it shall remain binding upon us and may be accepted at any time before the expiration of that period;
- (e) If our bid is accepted, we commit to obtain a performance security in accordance with the Bidding Documents;
- (f) We are not participating, as a Bidder or as a subcontractor, in more than one bid in this bidding process in accordance with ITB 4.3(e), other than alternative bids submitted in accordance with ITB 13;
- (g) We, along with any of our subcontractors, suppliers, consultants, manufacturers, or service providers for any part of the contract, are not debarred by any Procuring Entity under the State / UT Government, the Central Government, Autonomous body, Authority by whatever name called under them, UNOPS, UNDP, SAMS or GFATM as on the date of opening of bids;
- (h) We hereby certify that we have taken steps to ensure that no person acting for us or on our behalf will engage in any activities which is in contravention of the Code of Integrity proscribed in ITB Para 3 of the Bidding Documents;
- (i) We hereby certify that we are neither associated nor has been associated directly or indirectly with the consultant or any other entity that has prepared the design, specifications and other documents for the subject matter of procurement or is being proposed as Project Manager for the contract

- (j) We hereby certify that we have fulfilled our obligations to pay all such taxes as payable to the Central Government or the State Government or any local authority;
- (k) We hereby certify that we are not insolvent, in receivership, bankrupt or being wound up, not have its affairs administered by a court or a judicial officer, not have its business activities suspended and must not be the subject of legal proceedings for any of the foregoing reasons;
- (l) We hereby certify that our directors and officers have not been convicted of any criminal offence related to their professional conduct or the making of false statements or misrepresentations as to their qualifications to enter into a procurement contract within a period of three years preceding the commencement of the procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
- (m) We hereby certify that we are Class – I Local Suppliers as per the order Ref. No. P-45021/2/2017-PP (BE-II) dated 16 September, 2020 issued by Department for Promotion of Industry and Internal Trade (DPIIT), Ministry of Commerce and Industry, Govt. of India;
- (n) I/We hereby declare that we have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India and on sub-contracting to contractors from such countries. I/We certify that our Organization _____ (add name and address of registered office of bidder / consortium partner, if any) is not from such a country, or if from such a country, has been registered with the Competent Authority and will not subcontract any work to a contractor from such countries unless such contractor is registered with the competent authority (wherever applicable, evidence of valid registration by the Competent Authority shall be attached). I/We hereby certify that our organization fulfils all requirements in this regard and is eligible to be considered.
- (o) We understand that this bid, together with your written acceptance thereof included in your notification of award, shall constitute a binding contract between us, until a formal contract is prepared and executed; and

Name of the Bidder

Name of the person duly authorized to sign the Bid on behalf of the Bidder

Title of the person signing the Bid

Signature of the person named above

Date signed

Bidder Information Form

[The Bidder shall fill in this Form in accordance with the instructions indicated below. No alterations to its format shall be permitted and no substitutions shall be accepted.]

Date: *[insert date (as day, month and year) of Bid Submission]*

Bid Ref. No.: *[insert number of bidding process]*

1. Bidder's Name <i>[insert Bidder's legal name]</i>
2. Bidder's year of registration: <i>[insert Bidder's year of registration]</i>
3. Bidder's Address: <i>[insert Bidder's legal address]</i>
4. Bidder's Authorized Representative Information Name: <i>[insert Authorized Representative's name]</i> Address: <i>[insert Authorized Representative's Address]</i> Telephone/Fax numbers: <i>[insert Authorized Representative's telephone/fax numbers]</i> Email Address: <i>[insert Authorized Representative's email address]</i>
5. Attached are copies of original documents of <i>[check the box(es) of the attached original documents]</i> <input type="checkbox"/> Articles of Incorporation (or equivalent documents of constitution or association), and/or documents of registration of the legal entity named above, in accordance with ITB 4.3. <input type="checkbox"/> Organizational chart, a list of Board of Directors, and the beneficial ownership. <input type="checkbox"/> GSTIN Registration Certificate <input type="checkbox"/> Any other document

Technical Specification Compliance

Bidders must complete the table below.

Name of Equipment: Sch. 1 Silent Diesel Generator (DG) Set

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	Scope of work: Supply, Installation, Testing and Commissioning of silent type Diesel generator set of about 125 KVA capacity, complete with exhaust piping, earthing all accessories with Automatic Main Failure (AMF) panel including Bypass switch along with Standard Features, spares, accessories and handing it over to the site, thereafter.	
	D.G Set shall comprise of: -	
a)	Engine: - Four stroke cycle (air cooled up to 15 KVA and water cooled above 20 KVA), electric start, developing required brake horsepower (BHP) at 1500 revolution per minute (RPM) under continuous duty conditions. The engine shall be designed to run continuously, confirming to BS: 5514/ DIN-6271/IS 10001/IS 10002/ ISO – 3046. with an overload capacity of 10% for one hour in any 12 hours continuous under standard reference conditions. The diesel engine model shall be tested & certified for complying with CPCB (Central Pollution Control Board) norms. The engine shall be complete with standard accessories, spares and tools as detailed below: -	
i.	Radiator with fan	
ii.	Exhaust gas turbocharger	
iii.	Residential type silencer with required length of exhaust pipe	
iv	Air cleaner	
v	Fuel lift pump	
vi	Lube oil filter	
vii	Fuel filter	
viii	Heavy Duty dynamically balanced flywheel	
ix	Electronic governor	
x	Starter with suitable capacity battery	
xi	Battery charging unit of suitable capacity for equipment	
xii	Microprocessor based DG set control panel	
	<ul style="list-style-type: none"> consisting of engine safety module with built in ON/OFF/Start key, emergency stop, Lube oil pressure switch gauge, battery charging voltmeter, hour meter, coolant temperature gauge controller. 	
	<ul style="list-style-type: none"> Alarms & indications: Low Lube oil pressure, high coolant temperature, low coolant temperature, weak battery warning, sensor failure indication, over speed shut down system etc. 	
b)	Alternator: - The alternator shall be rated capacity at 0.8 power factor, 415 volts, 3 phase, 4 wire, 50 cycles/sec, 1500 rpm, self-excited and self-regulated, with brush less excitation. Band of voltage regulation shall be +2.5% of rated voltage from no load to full load. Insulation class shall be "H" for temperature rise consideration. The alternator shall be designed to withstand tropical/Indian geographical conditions. Required output shall be under NTP (Normal Temperature and Pressure) conditions. The alternator shall comply with BS 2613/IS 4722/IEC 34, latest edition.	
c)	Base Frame & Mounting Arrangement: -	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	The engine and the alternator shall be directly coupled to each other by means of couplings to form compact arrangement. Cooling system, engine and alternator units need to be mounted on a rigid fabricated Mild Steel common base frame. The base frame of the diesel generating set must be sturdy and fabricated/ welded construction out of Mild Steel channel iron base of suitable size for mounting the above the engine and alternator. The base frame must be suitably designed to simplify the transportation, handling, slinging, erecting, and commissioning. The base frame must be painted with anti-corrosive epoxy painting. A set of anti-vibration pads must be provided between base frame and engine alternator.	
d)	Battery: - Suitable shield maintenance free (SMF) batteries of standard make with leads and terminals shall be part of the equipment. The pack must be suitably positioned and to be easy withdrawal for the service. The battery pack must be minimum 180 AH.	
e)	Fuel Tank: - Fuel Tank must be located nearest to the DG set enclosure and ensure the diesel free flow. Suitable capacity of fuel tank needs to run the DG set for about minimum of 12 hours. The fuel tank must consist of mounting bracket, level indicator, fuel inlet, fuel outlet, air vent, drain plug, inlet arrangement for direct filling and set of hoses for inlet and return. Fuel consumption: ¼th of the total KVA rating or better on 100 % (full) load.	
f)	Exhaust Piping: - The exhaust piping shall be of suitable size and dimensions as per manufacturers recommendations meeting the hospital standards and need to be customized as per the site requirements. The residential silencer must be provided to minimize the noise level with hospital setup conditions. The exhaust piping must be insulated with heat resistant material (asbestos and/ glass wool) and clamped/supported, mounted on the wall/ floor with suitable size clamp. Outlet of exhaust shall be taken out from the structure as per site conditions and covered to protect from atmosphere effects like rain etc. The exhaust piping must be plastered after completion of all the work. The material of piping shall be of approved make and quality of Mild Steel with necessary bends and flanges (for indoor installations).	
g)	Acoustic Enclosure: The enclosure must be CPCB (Central Pollution Control Board) approved with soundproof enclosure. The enclosure must be modular construction with hinge bolted structure to provide easy dismantling and reassembling. The DG set with enclosure shall undergo strict quality checks and testing to achieve high-end performance so that the offered DG set with enclosure enables the sound reduction and thus as per latest CPCB norms of noise at 1 Mtr. distance under free condition should be 75 db. The Acoustic enclosure should be incorporated following:	
i.	The base plate fabricated with sheet metal of suitable thickness.	
ii.	The roof, sidewalls, integral partition, and doors shall be sandwich design made from good quality CRCA (cold rolled close annealed) sheet steel.	
iii.	The Acoustic enclosure shall be naturally cooled to maintain approximate temperature difference with ambient air of 70 deg C and if required forced ventilation shall also be considered.	
iv	The sound absorption material is selected from either glass wool/PU foam/ PVC foam of relevant thickness and density to have higher sound absorbing coefficient with low thermal conductivity to meet the performance.	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
v	The enclosure construction shall provide sufficient access for maintenance work. The door handles should be lockable type.	
vi	The control panel must be suitably mounted inside the DG set enclosure and enclosure door is provided with panel viewing window made from glass/ Acrylic and sealed with high quality Rubber gasket.	
vii	The enclosure shall be complete with:	
	Arrangement for power cable connection for load and mains supply	
	Integral- Residential Exhaust Silencer	
	Suction Louvers	
	Discharge Louvers	
	Open able & lockable doors with airtight, high quality rubber gasket	
	Interior lighting arrangement with ON/OFF switch on control panel as per the DG set size & Lifting arrangement	
	The engine and alternator must be flexibly coupled, aligned, and mounted with suitable anti vibration mountings.	
h)	<p>Installation of D.G. Set: - R.C.C. Foundation: The D.G. set shall be installed on suitable R.C.C. foundation after preparing the excavation pit, R.C.C. foundation bed etc. of requisite size, length and dimensions shall be provided. The quantity of R.C.C. material shall be as per manufacturer's design.</p> <p>Erection of D.G. set: The base frame on which the engine and the alternator are mounted shall be tightened to rag bolts if required with proper levelling and alignment. The supplier needs to fill the diesel tank full on installation and initial battery charging, onsite fuel consumption testing, load trial, transportation and unloading of DG set.</p>	
	<p><u>Automatic Main Failure (AMF) control Panel with bypass / change over switch</u> Automatic start of 125 KVA Generator sets on main supply electrical failure without requiring any human intervention. Similarly on restoration of mains supply it shall be able to transfer the load to mains supply and switch off the Generator set automatically (auto on and off). The Control panel shall be designed for automatic on mains failure' operation of the generator set. The panel must be in built design (inside acoustic enclosure) cubicle pattern and fabricated out of 16 SWG. Mild steel Sheet treated with anti-corrosion and painted with two coats of approved quality shade synthetic enamel / Power coated paint and appropriate ventilating arrangement. AMF should be ideally located near by the Low tension (LT) distribution panel of the laboratory. The panel shall be complete with the following:</p>	
i.	Molded Case Circuit Breaker (MCCB) suitably rated with standard accessories.	
ii.	Contactors of suitable rating.	
iii.	Neutral isolation contactor of suitable relays.	
iv	Set of control fuses and auxiliary relays.	
v	Set of tinned Copper busbars of suitable rating.	
vi	Automatic battery charger circuit having variable input voltage from 180-230V but the constant output DC voltage, with ON/OFF switch, with ON indication, reverse polarity indication, DC battery charging ammeter.	
vii	Engine on-off (push button type).	
viii	Microprocessor based AMF logic controller with following features:	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	(1) 3 Phase sensing of mains failure	
	(2) Impulse start of DG Set	
	(3) Off/Manual/Auto/Test selector switch	
	(4) Sensing of mains voltage presence	
	(5) Engine idling/cooling	
	(6)Mains metering on one common screen (three phase) by providing load manager	
	(7) Digital Voltmeter	
	(8) Digital Ammeter	
	(9) Digital Frequency	
	(10) Digital KW meter	
	(11) Digital Power Factor meter	
	(12) Digital KWh meter	
ix	All other electrical/electronic components required for the functioning of the AMF control panel as per manufacturer's design/guidelines.	
	Indications/alarm	
	Five number- indicating lamps to indicate mains low voltage, load on mains, set running, load on set and battery charger on.	
	Audio visual alarm for low liberating oil pressure, high water temperature, high cylinder head temperature, start failure and DG overload.	
	Common alarm for engine failure	
	Set of Red Yellow Blue (RYB) indicating lamps for generator supply	
	The components used in the fabrication of the panel shall be of standard quality/ reliability and shall be of reputed make, the spares of which are readily available in the local market.	
	Earthing: suitable earthing arrangement will be provided. Four number of earth sets for DG set as below:	
	GI Plate earthing (2 sets) body earthing	
	Copper earthing (2 sets) neutral earthing	
	Documentation:	
	1 set of following documents shall be provided with each set: - <ul style="list-style-type: none"> o Test Certificate of diesel engine. o Test certificate of Alternator. o Test Certificate of D.G. Set 	
	One set of operating manuals and two sets of control circuit drawing of panel in laminated form for the record purpose shall be provided.	
	The standard diagrams (Electrical & Electronics) and documents must be supplied along with the D. G. Set.	
	Painting: All equipment shall be suitably cleaned, painted, and protected against corrosion and damage.	
	Training:	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	Training should be provided to the site personals on D. G. Set operations and maintenance at the time of installation.	
	<p>Warranty:</p> <p>- All the equipment shall be guaranteed against unsatisfactory performance and/ or break down due to defective design, workmanship, or material for a period of two years from the date of commissioning at the site. The equipment or components or any part thereof or consumable items like (lube oil, all filters etc.), so found defective/required for routine replacement during the guarantee/ warranty period shall be forthwith repaired or replaced free of cost to the entire satisfaction of the site.</p> <p>-Supplier to arrange periodic preventive maintenance and breakdown service visit during the two years of warranty period.</p>	
	<ul style="list-style-type: none"> • First preventive maintenance is at 50 hours or 1 month from the date of commissioning, whichever occurs first, the first preventive maintenance is very important and mandatory, to be execute with zero tolerance. 	
	<ul style="list-style-type: none"> • Next Preventive maintenance is to be done at every 300 Hours or half yearly from the date of commissioning, whichever occurs first with replacement of consumables / any part of DG set. 	
	<ul style="list-style-type: none"> • Subsequent Preventive maintenance is to be done at every 600 Hours or 1 year from the date of commissioning, whichever occurs first with replacement of consumables / any part of DG set. 	
	<ul style="list-style-type: none"> • Service call to be attended as and when required within 24 -48 hrs. of time. 	
	<ul style="list-style-type: none"> • Any additional service visit as per manufacturer standards or recommendation 	
	<p><u>Maintenance: Works need to be covered during AMC period (after completion of the two-year of warranty period):</u></p>	
I.	Mechanical work (monthly basis):	
a	Checking the engine for its smooth running, unusual noise and colour of the smoke from the exhaust.	
b	Checking and adjusting fan belt tensions. Changing of the same if required.	
c	Cleaning of the Air filters to increase their life as well as proper inflow of air and replace if required.	
d	Checking for conditioning of coolant level and refill if required.	
e	Checking for conditioning of lube oil level and refill if required.	
f	Carrying out valve tappet setting as and when required.	
g	Checking of mounting bolts and replace if required.	
h	Checking for the proper functioning of engine safety like high water temperature gauge, oil pressure gauge, oil temperature gauge etc.	
i	Checking of turbo charger and accessory drive whenever required	
j	Checking the alignment of engine and alternator.	
k	Checking of proper functioning of instrument panel and AMF panel.	
l	Greasing of alternator bearing as per manufacturer recommendation.	
m	Fuel system	
	<ul style="list-style-type: none"> • Checking and maintenance of fuel system including fuel tank, fuel piping, fuel valve etc. 	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make: Model:.....
	<ul style="list-style-type: none"> Any leakage from the fuel line system to be repaired. 	
n	Exhaust system	
	<ul style="list-style-type: none"> Checking and maintenance of exhaust silencer and exhaust stack etc. Any smoke leakage from the exhaust system to be repaired. Checking of insulation of exhaust piping. Carry out any other periodic maintenance check as per OEM checklist. 	
II.	Electrical work (monthly basis):	
a	Checking and fault finding associated with the electrical systems of the engine.	
b	General cleaning of alternator of the DG set.	
c	Cleaning of battery terminals & de-sulphation and checking its functionality.	
d	Checking of wiring system for any loose and resolving it.	
e	Maintenance for smooth functioning if different parameters in generator engine and AMF panel.	
f	Diagnosis of various electrical faults and rectification at site.	
g	Fault rectification of AMF panel along with accessories.	
h	Maintenance of earth resistance and measuring of earth resistance on quarterly basis.	
III	A proper Logbook for Service Record must be maintained	
IV	Material / spares which are not covered under standard AMC, will be in the scope of user/ client side.	

Name of Equipment: Sch. 2 Servo Controlled Automatic Voltage Stabilizer

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	Generic	
	<ul style="list-style-type: none"> • Servo Controlled Automatic Voltage Stabilizer 	
	<ul style="list-style-type: none"> • Capacity rating: 175 KVA/ 150 KVA/ 120 KVA/ 100KVA/ 60 KVA 	
	<ul style="list-style-type: none"> • No of phase: Three phase 	
	Constructional	
	<ul style="list-style-type: none"> • Control type: Digital Microcontroller based 	
	<ul style="list-style-type: none"> • Input voltage ranges: 170-280V AC phase voltage, (3 phase: 340-490 V) 50 HZ 	
	<ul style="list-style-type: none"> • Output voltage ranges: 415 V \pm1 % (adjustable between 390 V-420 V) AC 	
	<ul style="list-style-type: none"> • Type of cooling: Oil cooled (including first filling of cooling oil) 	
	<ul style="list-style-type: none"> • Transformer (s) winding material: copper 	
	<ul style="list-style-type: none"> • Indicator: Input & output voltmeter and ampere meter should be separate for each three phases. All meters should be digital only. <ul style="list-style-type: none"> a) Input phase to neutral b) Input phase to phase c) Output phase to neutral d) Output phase to phase e) Load current in all three phases f) Frequency 	
	<ul style="list-style-type: none"> • Manual bypass switch shall be provided in case any breakdown we can bypass incoming raw power 	
	<ul style="list-style-type: none"> • Suitable rated Miniature Circuit Breaker (MCB) shall be provided 	
	<ul style="list-style-type: none"> • Size: <ul style="list-style-type: none"> a) 175 KVA: approx. 6' x 4' x 4'6" (L X W XH) b) 150/120/100 KVA: approx. 5' x 4' x 4' (L X W XH) c) 60 KVA: approx. 4' x 3' x 4' (L X W XH) 	
	<ul style="list-style-type: none"> • Enclosure: Mild steel cabinet with powder coating 	
	<ul style="list-style-type: none"> • Environment: Indoor continuous operation 	
	<ul style="list-style-type: none"> • Mounting: on wheels 	
	<ul style="list-style-type: none"> • Input and output cable terminals: suitable heavy-duty copper/ brass connectors shall be provided for connection 	
	<ul style="list-style-type: none"> • Earth terminal: suitable terminal stud shall be provided 	
	<ul style="list-style-type: none"> • System construction as per IS 9815. 	
	Functional	
	<ul style="list-style-type: none"> • Compatible to Generator supply 	
	<ul style="list-style-type: none"> • Efficiency: above 98 % 	
	<ul style="list-style-type: none"> • Power factor: minimum of 0.8 	
	<ul style="list-style-type: none"> • Continuous duty: yes (100%) 	

Sl. No.	Bid Technical Specification (Main)	Bidder's Specification (technical compliance/ Deviation, if any)
		Make:
		Model:.....
	<ul style="list-style-type: none"> Effect on Load power factor: NIL 	
	<ul style="list-style-type: none"> Waveform Distortion: NIL 	
	<ul style="list-style-type: none"> Connection: star 	
	<ul style="list-style-type: none"> Operating frequency: 50 HZ 	
	<ul style="list-style-type: none"> Trip and restart: Auto system 	
	<ul style="list-style-type: none"> Reset: Manual/ auto reset with time delay 	
	<ul style="list-style-type: none"> System: both balanced and unbalanced 4 wire Red Blue Yellow Neutral (R B Y N) 	
	<ul style="list-style-type: none"> Response time: less than 100 milli second 	
	<ul style="list-style-type: none"> Correction speed: Approx. 70 V/sec or better 	
	<ul style="list-style-type: none"> Overload capacity: 120 % 	
	<ul style="list-style-type: none"> Insulation: minimum Class B 	
	<ul style="list-style-type: none"> Operating temperature: 0- 45 deg C 	
	<ul style="list-style-type: none"> Provisioning of cabling: Input and output terminals with provision for fixing cable glands (cable requirement will vary for site to site) 	
	Protection	
	<ul style="list-style-type: none"> Electronic over and under voltage trip with time delay 	
	<ul style="list-style-type: none"> Electronic overload protection 	
	<ul style="list-style-type: none"> Single phase prevention protection and cutoff 	
	<ul style="list-style-type: none"> Phase reversal protection and cutoff 	
	<ul style="list-style-type: none"> Audio visual alarm is required for tripping conditions 	
	Certification	
	<ul style="list-style-type: none"> The manufacturer must have a management system certified to ISO 9001. Quality and safety standards met by the product to be listed. 	
	<ul style="list-style-type: none"> The Voltage stabilizer should have Conformité Européenne (CE) or IS 9815. 	
	Warranty: The manufacturer / bidder should provide standard two-years of warranty and comprehensive maintenance services (CMC) and should be able to provide Annual Maintenance Contract (AMC) after completion of warranty period.	
	Installation & Commissioning: The manufacturer / bidder should arrange onsite installation and commissioning of Voltage stabilizer in coordination with the local electrical/Public Work Department (PWD) engineer/ site in charge.	

Letter of Financial Bid

Form FIN I - Price Bid Form

[to be submitted with Price Bid only]

To,
M/s Strategic Alliance Management Services Pvt. Ltd. (SAMS),
B-18, Sector-6, Noida,
G.B. Nagar – 201301 (U.P.)

Dear Sir,

Subject: Bid for supply, installation, testing and commissioning of Silent Diesel Generator (DG) Set and Servo Controlled Automatic Voltage Stabilizer across TB Labs under the National Tuberculosis Elimination Programme (NTEP)

Bid Ref. No. SAMS/FIND India/Proc./Equipment/ATI/4/2022

1. We, [**Name of Bidder**], hereby submit a bid for the construction of the above- referenced works in response to the above-referenced ITB for following Schedule:

Schedule No. (as many as quoted by the Bidder)	Name of Equipment

2. We warrant that in preparing and submitting this bid, we have complied with, and are willing to be bound by, any and all of the requirements and provisions of the above- referenced ITB, including the terms and conditions of the Contract as set out in the BidDocuments.
3. Based on the above, our proposed **Total Contract Price is Rs. _____ inclusive of all applicable taxes i.e. GST for..... schedules** (amount in words) and as per FIN-2 and FIN-3 Forms attached
4. I, the undersigned, certify that I am duly authorized by [**insert name of bidder**] to sign this bid and bind [**insert name of bidder**]:

Name: _____
Title: _____
Date: _____
Signature: _____

Form FIN-2 : Lump sum Contract Price

(To be submitted for each quoted Schedules individually)

Schedule No.

Description	Name of Equipment	Unit Cost	GST [%age & value]	Total Cost (inclusive of all applicable taxes (i.e. GST))
A. Cost of Financial Bid for supply, installation, testing and commissioning of Equipment along-with 2 years of warranty Note: Cost quoted should match with the total Cost as per Form FIN-3: Priced Bill of Quantity				
B. Cost of Annual Maintenance Services after completion of warranty period of 2years				
3 rd Year				
4 th Year				
5 th Year				
C= TOTAL BID PRICE = (A + B)				

¹ Please provide spare part price list (as Annexure-A to FIN-2) as may be required (and valid) during entire duration of annual maintenance services.

ANNEXURE-A

FORM FIN-2 – Price list of all necessary spare parts that may be required and should be valid during entire duration of annual maintenance services after completion of two years comprehensive warranty period.

Sr. No.	Name of Spare Part	Unit Price (exclusive of GST)
1		
2		
n		

Form FIN-3 Cost of Works

(To be submitted for each quoted Schedule with Price bid only)

Bidders shall submit detailed workings of Lump Sum Contract Price (Component-A as given in FIN-2) for supply, installation, testing and commissioning of Silent Diesel Generator (DG) Set and Servo Controlled Automatic Voltage Stabilizer across TB Labs under the National Tuberculosis Elimination Programme (NTEP). The total price mentioned in the table below should coincide with the Price Component A as given in FIN-2 for each Schedule.

**Schedule 1 – Supply of Silent Diesel Generator (DG) Set
Site 1 = Varanasi**

Sl. No.	D.G.SET WITH PANEL (BHU Varanasi)	UOM (unit of measurement)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
1	Supply, Installation, Testing and Commissioning (SITC) of 125 KVA silent type DG set with panel	No	1			
2	Supply, Installation, Testing and Commissioning (SITC) of Automatic Main Failure (AMF) panel including Bypass switch along with stand that will be suitable to DG Set	No	1			
3	Cable tray with cover and its accessories; 150 x 25mm (W x H) - (16 SWG - 1.6mm) with cover, perforated cable tray from MS sheet and then hot dip galvanised and associated accessories such as coupler plates, tees, elbow etc.	Rmtr.	10			
4	RCC platform work after preparing the excavation pit with associated civil work and MS Structural for Shed for DG set: DG set shed with provision for fencing, door with lock-key arrangement. a. Framework vertically made of M S Square Pipe frame: 2 Inches X 2 Inches, 16 Gauge b. M S Fencing with wire mesh: ½ inch X ½ inch c. Supporting Structure M S Angle: 50 X 5 mm d. GI pre-coated corrugated profile roof sheet: 0.5 mm thick duly supported with J Hook. e. 10 SWG with provision of door with lock and key DG set Shed with fencing should be duly enamel painted and with anti-rust coating from both sides. The height covered shall be at least 9 feet or as suitable to the DG set. There should be no gap between roof sheet and wire mesh, if any angle creates gap, it should be covered with iron bars and wire mesh in between	Job	1			

Sl. No.	D.G.SET WITH PANEL (BHU Varanasi)	UOM (unit of measurement)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
5	Cabling work : compatible to DG set including labour cost; 3.5 C X 150 Sq.mm or as recommended by the company, Al conductor, XLPE insulated, extruded PVC inner and FRLS outer sheathed cables, cables shall be fitted on wall / ceiling by the means of saddle & spacers. Miscellaneous items such as cable dressing accessories like nylon tie, Aluminium clamps, GI cleats, cable tags etc. are included in the scope.	Mtr.	29			
6	Supplying & Laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by the company for connecting AMF Panel and Generator.	RMtr.	26			
7	GI Plate earthing (2 sets) body earthing including necessary electrodes Copper earthing (2 sets) neutral earthing including necessary electrodes	Job	1			
8	Supply and laying of Heavy duty reinforced cement concrete (RCC) Hume pipe for road crossing, below plinth beam of following size as diameter : 150mm Dia or as recommended by the company for enclosing provided cable & necessary back filling with light ramming to make the road/ground surface as it was original.	RMtr.	16			
9	Supply, erection, testing and commission of MS exhaust pipe with bends, flanges, rain cap & covers and all accessories complete in every way	Mtr.	12			
10	Transportation, Commissioning and Handling Charge	Job	1			
Total Amount						

**Schedule 1 – Supply of Silent Diesel Generator (DG) Set
Site 2 = RBIPMT**

Sl. No.	D.G.SET WITH PANEL (RBIPMT, Delhi)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
1	Supply, Installation, Testing and Commissioning (SITC) of 125 KVA silent type DG set with panel	No	1			
2	Supply, Installation, Testing and Commissioning (SITC) of Automatic Main Failure (AMF) panel including Bypass switch along with stand that will be suitable to DG Set	No	1			
3	RCC platform work after preparing the excavation pit with associated civil work and MS Structural for Shed for DG set: DG set shed with provision for fencing, door with lock-key arrangement. a. Framework vertically made of M S Square Pipe frame: 2 Inches X 2 Inches, 16 Gauge b. M S Fencing with wire mesh: ½ inch X ½ inch c. Supporting Structure M S Angle: 50 X 5 mm d. GI pre-coated corrugated profile roof sheet: 0.5 mm thick duly supported with J Hook. e. 10 SWG with provision of door with lock and key DG set Shed with fencing should be duly enamel painted and with anti-rust coating from both sides. The height covered shall be at least 9 feet or as suitable to the DG set. There should be no gap between roof sheet and wire mesh, if any angle creates gap, it should be covered with iron bars and wire mesh in between	Job	1			
4	Cabling work : compatible to DG set including labour cost; 3.5 C X 150 Sq.mm or as recommended by the company, Al conductor, XLPE insulated, extruded PVC inner and FRLS outer sheathed cables. Cables shall be fitted on wall / ceiling by the means of saddle & spacers. Miscellaneous items such as cable dressing accessories like nylon tie, Aluminium clamps, GI cleats, cable tags etc. are included in the scope.	Mtr.	50			
5	Supplying & Laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by the company for connecting AMF Panel and Generator.	RMtr.	10			

Sl. No.	D.G.SET WITH PANEL (RBIPMT, Delhi)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
6	GI Plate earthing (2 sets) body earthing including necessary electrodes Copper earthing (2 sets) neutral earthing including necessary electrodes	Job	1			
7	Supply and laying of Heavy duty reinforced cement concrete (RCC) Hume pipe for road crossing, below plinth beam of following size as diameter : 150mm Dia or as recommended by the company for enclosing provided cable & necessary back filling with light ramming to make the road/ground surface as it was original.	Mtr.	50			
8	Supply, erection, testing and commission of MS exhaust pipe with bends, flanges, rain cap & covers and all accessories complete in every way	Mtr.	10			
9	Transportation, Commissioning and Handling Charge	Job	1			
Total Amount						

**Schedule 1 – Supply of Silent Diesel Generator (DG) Set
Site 3 = Adilabad**

Sl. No.	D.G.SET WITH PANEL (RIMS, Adilabad)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
1	Supply, Installation, Testing and Commissioning (SITC) of 125 KVA silent type DG set with panel	No	1			
2	Supply, Installation, Testing and Commissioning (SITC) of Automatic Main Failure (AMF) panel including Bypass switch along with stand that will be suitable to DG Set	No	1			
3	<p>RCC platform work after preparing the excavation pit with associated civil work and MS Structural for Shed for DG set DG set shed with provision for fencing, door with lock-key arrangement.</p> <p>a. Framework vertically made of M S Square Pipe frame: 2 Inches X 2 Inches, 16 Gauge b. M S Fencing with wire mesh: ½ inch X ½ inch c. Supporting Structure M S Angle: 50 X 5 mm d. GI pre-coated corrugated profile roof sheet: 0.5 mm thick duly supported with J Hook. e. 10 SWG with provision of door with lock and key</p> <p>DG set Shed with fencing should be duly enamel painted and with anti-rust coating from both sides. The height covered shall be at least 9 feet or as suitable to the DG set. There should be no gap between roof sheet and wire mesh, if any angle creates gap, it should be covered with iron bars and wire mesh in between</p>	Job	1			
4	<p>Cabling work : compatible to DG set including labour cost; 3.5 C X 150 Sq.mm or as recommended by the company, Al conductor, XLPE insulated, extruded PVC inner and FRLS outer sheathed cables. Cables shall be fitted on wall / ceiling by the means of saddle & spacers. Miscellaneous items such as cable dressing accessories like nylon tie, Aluminium clamps, GI cleats, cable tags etc. are included in the scope.</p>	Mtr.	100			
5	Supplying & laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by the company for connecting AMF Panel and Generator.	RMtr.	95			

Sl. No.	D.G.SET WITH PANEL (RIMS, Adilabad)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
6	GI Plate earthing (2 sets) body earthing including necessary electrodes Copper earthing (2 sets) neutral earthing including necessary electrodes	Job	1			
7	Supply and laying of Heavy duty reinforced cement concrete (RCC) Hume pipe for road crossing, below plinth beam of following size as diameter : 150mm Dia or as recommended by the company for enclosing provided cable & necessary back filling with light ramming to make the road/ground surface as it was original.	Mtr.	90			
8	Transportation, Commissioning and Handling Charge	Job	1			
Total Amount						

**Schedule 1 – Supply of Silent Diesel Generator (DG) Set
Site 4 = Vijayawada**

Sl. No.	D.G.SET WITH PANEL (SMC, Vijayawada)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
1	Supply, Installation, Testing and Commissioning (SITC) of 125 KVA silent type DG set with panel	No	1			
2	Supply, Installation, Testing and Commissioning (SITC) of Automatic Main Failure (AMF) panel including Bypass switch along with stand that will be suitable to DG Set	No	1			
3	RCC platform work after preparing the excavation pit with associated civil work and MS Structural for Shed for DG set DG set shed with provision for fencing, door with lock-key arrangement. a. Framework vertically made of M S Square Pipe frame: 2 Inches X 2 Inches, 16 Gauge b. M S Fencing with wire mesh: ½ inch X ½ inch c. Supporting Structure M S Angle: 50 X 5 mm d. GI pre-coated corrugated profile roof sheet: 0.5 mm thick duly supported with J Hook. e. 10 SWG with provision of door with lock and key DG set Shed with fencing should be duly enamel painted and with anti-rust coating from both sides. The height covered shall be at least 9 feet or as suitable to the DG set. There should be no gap between roof sheet and wire mesh, if any angle creates gap, it should be covered with iron bars and wire mesh in between	Job	1			
4	Cabling work : compatible to DG set including labour cost; 3.5 C X 150 Sq.mm or as recommended by the company, Al conductor, XLPE insulated, extruded PVC inner and FRLS outer sheathed cables. Cables shall be fitted on wall / ceiling by the means of saddle & spacers. Miscellaneous items such as cable dressing accessories like nylon tie, Aluminium clamps, GI cleats, cable tags etc. are included in the scope.	Mtr.	90			
5	Supplying & Laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by	RMtr.	35			

Sl. No.	D.G.SET WITH PANEL (SMC, Vijayawada)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
	the company for connecting AMF Panel and Generator.					
6	GI Plate earthing (2 sets) body earthing including necessary electrodes Copper earthing (2 sets) neutral earthing including necessary electrodes	Job	1			
7	Supply and laying of Heavy duty reinforced cement concrete (RCC) Hume pipe for road crossing, below plinth beam of following size as diameter : 150mm Dia or as recommended by the company for enclosing provided cable & necessary back filling with light ramming to make the road/ground surface as it was original.	Mtr.	15			
8	160 A Bus bar chamber	No	1			
9	Transportation, Commissioning and Handling Charge	Job	1			
Total Amount						

**Schedule 1 – Supply of Silent Diesel Generator (DG) Set
Site 5 = Bikaner**

Sl. No.	D.G.SET WITH PANEL (SPMC Bikaner)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
1	Supply, Installation, Testing and Commissioning (SITC) of 125 KVA silent type DG set with panel	No	1			
2	Supply, Installation, Testing and Commissioning (SITC) of Automatic Main Failure (AMF) panel including Bypass switch along with stand that will be suitable to DG Set	No	1			
3	Cable tray with cover and its accessories; 150 x 25mm (W x H) - (16 SWG - 1.6mm) with cover, perforated cable tray from MS sheet and then hot dip galvanised and associated accessories such as coupler plates, tees, elbow etc.	Rmtr.	20			
4	RCC platform work after preparing the excavation pit with associated civil work and MS Structural for Shed for DG set: RCC platform with TMT bar cage will be required because existing drainage line 19(L)* 3 (W) needs to be covered. DG set shed with provision for fencing, door with lock-key arrangement. a. Framework vertically made of M S Square Pipe frame: 2 Inches X 2 Inches, 16 Gauge b. M S Fencing with wire mesh: ½ inch X ½ inch c. Supporting Structure M S Angle: 50 X 5 mm d. GI pre-coated corrugated profile roof sheet: 0.5 mm thick duly supported with J Hook. e. 10 SWG with provision of door with lock and key DG set Shed with fencing should be duly enamel painted and with anti-rust coating from both sides. The height covered shall be at least 9 feet or as suitable to the DG set. There should be no gap between roof sheet and wire mesh, if any angle creates gap, it should be covered with iron bars and wire mesh in between	Job	1			
5	Cabling work : compatible to DG set including labour cost; 3.5 C X 150 Sq.mm or as recommended by the company , Al conductor, XLPE insulated, extruded PVC	Mtr.	22			

Sl. No.	D.G.SET WITH PANEL (SPMC Bikaner)	Unit of Measurement (UOM)	Qty.	Unit Rate (in INR)	GST [%age & value]	Total Cost (inclusive of all taxes) (in INR)
	inner and FRLS outer sheathed cables. Cables shall be fitted on wall / ceiling by the means of saddle & spacers. Miscellaneous items such as cable dressing accessories like nylon tie, Aluminium clamps, GI cleats, cable tags etc. are included in the scope.					
6	Supplying & Laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by the company for connecting AMF Panel and Generator.	RMtr.	20			
7	GI Plate earthing (2 sets) body earthing including necessary electrodes Copper earthing (2 sets) neutral earthing including necessary electrodes	Job	1			
8	Supply, erection, testing and commission of MS exhaust pipe with bends, flanges, rain cap & covers and all accessories complete in every way	Mtr.	12			
9	Transportation, Commissioning and Handling Charge	Job	1			
Total Amount						

Schedule 2 – Supply of Servo Controlled Automatic Voltage Stabilizer

Sl. No.	State	Site	Per lab req. Qty. (3)	Capacity of Voltage stabilizer (VS) (4)	Cabling requirement (In meter) (5)	Unit Rate of Voltage stabilizer (in INR (including Logistics and installation) (6)	GST [%age & value] (7)	Total Cost of item (inclusive of all taxes) (in INR) (8) = (6) + (7) * (3)	Unit Rate of Cabling requirement (in INR (including Logistics (both loading & unloading) and installation) (9)	GST [%age & value] (10)	Total Cost of item (inclusive of all taxes) (in INR) (11) = (9) + (10) * (5)	Grand Total (in INR) including GST along with Unit cost of item and cabling requirement (12) = (8) + (11)
1	AP	Vijayawada SMC	1	120 KVA	0							
2	Assam	Guwahati	1	100 KVA	5							
3	Bihar	Bhagalpur	1	100 KVA	0							
4	Bihar	Patna IGIMS	1	100 KVA	20							
5	Uttar Pradesh	KGMU Lucknow	1	120 KVA	0							
6	Bihar	Pawapuri	1	150 KVA	0							
7	Chhattisgarh	Raipur IRL	1	175 KVA	31							
8	Chhattisgarh	Raigarh	1	100 KVA	5							
9	Delhi	RBIPMT Delhi	1	150 KVA	22							
10	Delhi	NDTC Delhi	1	120 KVA	10							
11	Goa	Goa GMC	1	60 KVA	16							
12	Gujarat	Surat GMC	1	100 KVA	3							
13	Haryana	Karnal IRL	1	150 KVA	10							
14	Haryana	Rohtak	1	100 KVA	3							
15	Jharkhand	Dhanbad PMC	1	150 KVA	3							
16	Karnataka	KIMS Hubli	1	175 KVA	10							
17	Karnataka	Raichur RIMS	1	175 KVA	15							
18	Kerala	Kozhikode GMC	1	100 KVA	14							
19	Maharashtra	Aurangabad GMC	1	150 KVA	65							
20	Maharashtra	Nagpur IRL	1	120 KVA	0							
21	Maharashtra	Akola	1	150 KVA	25							
22	Meghalaya	Shillong	1	175 KVA	4							
23	Mizoram	Aizawl	1	100 KVA	4							
24	MP	Gwalior GRMC	1	175 KVA	0							
25	MP	NIRTH Jabalpur	1	175 KVA	5							

Sl. No.	State	Site	Per lab req. Qty. (3)	Capacity of Voltage stabilizer (VS) (4)	Cabling requirement (In meter) (5)	Unit Rate of Voltage stabilizer (in INR (including Logistics and installation) (6)	GST [%age & value] (7)	Total Cost of item (inclusive of all taxes) (in INR) (8) = (6) + (7) * (3)	Unit Rate of Cabling requirement (in INR (including Logistics (both loading & unloading) and installation) (9)	GST [%age & value] (10)	Total Cost of item (inclusive of all taxes) (in INR) (11) = (9) + (10) * (5)	Grand Total (in INR) including GST along with Unit cost of item and cabling requirement (12) = (8) + (11)
26	MP	Bhopal	1	175 KVA	14							
27	Nagaland	Kohima	1	100 KVA	4							
28	Odisha	RMRC Bhubaneswar	1	100 KVA	4							
29	Odisha	Cuttack IRL	1	100 KVA	4							
30	Punjab	Faridkot	1	150 KVA	0							
31	Rajasthan	Ajmer IRL	1	175 KVA	10							
32	Rajasthan	Jodhpur IRL	1	175 KVA	50							
33	Rajasthan	Bikaner	1	150 KVA	4							
34	Sikkim	Gangtok IRL	1	100 KVA	7							
35	Tamil Nadu	Madurai MMC	1	120 KVA	10							
36	Telangana	Hyderabad IRL	1	100 KVA	7							
37	Telangana	Adilabad RIMS	1	150 KVA	0							
38	Telangana	Warangal	1	100 KVA	5							
39	Tripura	Agartala GMC	1	150 KVA	6							
40	UP	Varanasi BHU	1	120 KVA	5							
41	UP	Aligarh JNMC	1	100 KVA	25							
42	UP	LLRMC Meerut	1	175 KVA	15							
43	UP	Kanpur Nagar	1	150 KVA	5							
44	UP	Jhansi	1	150 KVA	5							
45	Uttarakhand	Dehradun IRL	1	60 KVA	5							
46	West Bengal	Siliguri IRL	1	100 KVA	4							
47	West Bengal	Kolkata IRL	1	120 KVA	5							
48	West Bengal	Bardhaman GMC	1	120 KVA	4							
49	West Bengal	Murshidabad	1	100 KVA	20							
50	MP	IRL Indore	1	175 KVA	5							
51	West Bengal	Medinipur	1	100 KVA	10							
Grand Total			51									

Form of Bid Security Declaration

[Please refer to ITB Para 17 of the Bid Document]

[The Bidder shall fill in this form in accordance with the instructions indicated below. No alterations to its format shall be permitted and no substitutions shall be accepted.]

Date: *[date (as day, month and year)]*

Bid Ref. No.: *[number of bidding process]*

Ref:

To

The Director
M/s Strategic Alliance Management
Services Pvt. Ltd. B-18, Sector-6,
Noida, G.B. Nagar
Uttar Pradesh – 201301

We, the undersigned, declare that:

We understand that, according to your conditions, bids must be supported by a Bid Securing Declaration.

We accept that we will automatically be suspended from being eligible for bidding in any contract with the Purchaser for the period of 2 (two) years starting on *the date of suspension*, if we are in breach of our obligation(s) under the bid conditions, because we:

- (a) have withdrawn our Bid during the period of bid validity specified in the Letter of Technical Bid; or
- (b) having been notified of the acceptance of our Bid by the Purchaser during the period of bid validity, (i) fail or refuse to execute the Contract; or (ii) fail or refuse to furnish the Performance Security, if required, in accordance with the ITB.

We understand this Bid Securing Declaration shall expire if we are not the successful Bidder, upon the earlier of (i) our receipt of your notification to us of the name of the successful Bidder; or (ii) twenty-eight days after the expiration of our Bid.

Name of the Bidder _____

Name of the person duly authorized to sign the Bid on behalf of the Bidder _____

Title of the person signing the Bid _____

Signature of the person named above _____

Date signed _____

Manufacturer's Authorization

*[The Bidder shall require the Manufacturer to fill in this Form in accordance with the instructions indicated. This letter of authorization should be on the letterhead of the Manufacturer and should be signed by a person with the proper authority to sign documents that are binding on the Manufacturer. The Bidder shall include it in its bid, if so indicated in the **BDS**.]*

Date: *[insert date (as day, month and year) of Bid Submission]*

Bid Ref. No.: *[insert number of bidding process]*

To: *[insert complete name of Purchaser]*

WHEREAS

We *[insert complete name of Manufacturer]*, who are official manufacturers of *[insert type of goods manufactured]*, having factories at *[insert full address of Manufacturer's factories]*, do hereby authorize *[insert complete name of Bidder]* to submit a bid, the purpose of which is to provide the following Goods, manufactured by us *[insert name and or brief description of the Goods]*, and to subsequently negotiate and sign the Contract.

We hereby extend our full guarantee and warranty in accordance with Clause 29 of the General Conditions of Contract, with respect to the Goods offered by the above firm.

Signed: *[insert signature(s) of authorized representative(s) of the Manufacturer]*

Name: *[insert complete name(s) of authorized representative(s) of the Manufacturer]*

Title: *[insert title]*

Dated on _____ day of _____, _____ *[insert date of signing]*

Proforma for Performance Statement (for a period of last three years)

Name of the Firm _____

Order placed by (full address of Purchaser)	Order No. and Date	Description and quantity of ordered goods	Value of order	Date of completion of delivery		Remarks indicating reasons for late delivery, if any	Has the supply of goods been satisfactory performance? *
				As per contract	Actual		
1	2	3	4	5	6	7	8

Signature and seal of the Bidder

The Bidder shall also furnish the following documents in connection with their past performance:

- i. Copy of Purchase Orders
- ii. Copy of Invoices
- iii. Proof of Payment received from Purchasers
- iv. Documentary evidence (Client's certificate) in support of satisfactory completion of contract

Proforma for Other Details of Bidder, Manufacturer and its Bank

1. Name & full address of the Manufacturer:

2. (a) Telephone & Fax No Office /Works
 (b) Email

3. Location of the manufacturing factory.

4. Name & full address of the Bidder

5. (a) Telephone/Mobile & Fax No Office/Factory/Works
 (b) Email

6. Details of two Persons that Purchaser may contact for requests for clarification during bid evaluation:

	1 st	2 nd
(i) Name:		
(ii) Tel number (direct):		
(iii)Mobile No.		
(iv) Email address		

7. Bank details from where the Bank Guarantee for Bid Security has been issued:

- (i) Name and address of the Bank:
- (ii) Name of the contact Person
- (iii) Phone number/Mobile
- (iv) Fax Number
- (v) Email address

Signature and seal of the Bidder

Section IX – General Conditions of Contract

Table of Clauses

1. Definitions.....	- 82 -
2. Contract Documents.....	- 82 -
3. Code of Integrity.....	- 83 -
5. Language.....	- 85 -
6. Joint Venture or Consortium.....	- 85 -
7. Eligibility.....	- 85 -
8. Notices.....	- 86 -
9. Governing Law.....	- 86 -
10. Settlement of Disputes.....	- 86 -
11. Inspections and Audit by the Purchaser.....	- 86 -
12. Scope of Supply.....	- 87 -
13. Delivery and Documents.....	- 87 -
14. Supplier's Responsibilities.....	- 87 -
15. Contract Price.....	- 87 -
16. Terms of Payment.....	- 87 -
17. Taxes and Duties.....	- 88 -
18. Performance Security.....	- 88 -
19. Copyright.....	- 88 -
22. Subcontracting.....	- 90 -
24. Packing and Documents.....	- 91 -
25. Insurance.....	- 91 -
26. Transportation and Incidental Services.....	- 91 -
27. Inspections and Tests.....	- 92 -
28. Liquidated Damages.....	- 92 -
29. Warranty.....	- 93 -
30. Limitation of Liability.....	- 93 -
31. Change in Laws and Regulations.....	- 93 -
32. Force Majeure.....	- 94 -
34. Extensions of Time.....	- 95 -
36. Assignment.....	- 96 -

Section VII. General Conditions of Contract

1. Definitions

1.1 The following words and expressions shall have the meanings hereby assigned to them:

- (a) "Contract" means the Contract Agreement entered into between the Purchaser and the Supplier, together with the Contract Documents referred to therein, including all attachments, appendices, and all documents incorporated by reference therein.
- (b) "Contract Documents" means the documents listed in the Contract Agreement, including any amendments thereto.
- (c) "Contract Price" means the price payable to the Supplier as specified in the Contract Agreement, subject to such additions and adjustments thereto or deductions therefrom, as may be made pursuant to the Contract.
- (d) "Day" means calendar day.
- (e) "Completion" means the fulfilment of the Related Services by the Supplier in accordance with the terms and conditions set forth in the Contract.
- (f) "GCC" means the General Conditions of Contract.
- (g) Goods may include all articles, material, commodities, electricity, livestock, furniture, fixtures, raw material, spares, instruments, software, machinery, equipment, industrial plant, vehicles, aircraft, ships, railway rolling stock and any other category of goods, whether in solid, liquid or gaseous form, purchased or otherwise acquired for the use of a procuring entity as well as services or works incidental to the supply of goods of the value of services or works or both does not exceed that of the goods themselves.
- (h) "Purchaser" means the entity purchasing the Goods, **as specified in the SCC.**
- (i) "SCC" means the Special Conditions of Contract.
- (j) "Subcontractor" means any person, private or government entity, or a combination of the above, to whom any part of the Goods to be supplied or execution of any part of the Related Services is subcontracted by the Supplier.
- (k) "Supplier" means the person, private or government entity, or a combination of the above, whose bid to perform the Contract has been accepted by the Purchaser and is named as such in the Contract Agreement.
- (l) "Consignee Location" means the place named in the **Schedule of Requirements.**

2. Contract Documents

2.1 Subject to the order of precedence set forth in the Contract Agreement, all documents forming the Contract (and all parts thereof)

are intended to be correlative, complementary, and mutually explanatory. The Contract Agreement shall be read as a whole.

3. Code of Integrity

3.1 The Purchaser and all officers or employees of the purchaser, whether involved in the procurement process or otherwise, or Bidders and their representatives or consultants or service providers participating in a procurement process or other persons involved, directly or indirectly in any way in a procurement process shall maintain an unimpeachable standard of integrity.

3.2 Purchaser prescribes to the its personnel and Bidders to uphold the Code of Integrity, which prohibits officers or employees of a Purchaser or a person participating in a procurement process the following:

- (i) any offer, solicitation or acceptance of any bribe, reward or gift or any material benefit, either directly or indirectly, in exchange for an unfair advantage in the procurement process or to otherwise influence the procurement process;
- (ii) any omission, including a misrepresentation that misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- (iii) any collusion, bid rigging or anti-competitive behaviour to impair the transparency, fairness and progress of the procurement process;
- (iv) improper use of information shared between the procuring entity and the bidders with an intent to gain unfair advantage in the procurement process or for personal gain;
- (v) any financial or business transactions between the bidder and any officer or employee of the Purchaser, who are directly or indirectly related to tender or execution process of contract;
- (vi) any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- (vii) any obstruction of any investigation or audit of a procurement process;
- (viii) making false declaration or providing false information for participation in -

- a) tender process or to secure a contract;
- b) disclosure of Conflict of Interest;
- c) disclosure by the bidder of any previous transgressions with any entity in India or any other country during the last three years or of any debarment by any other Procuring Entity

3.3 In case of any breach of the Code of Integrity by a bidder or a prospective bidder, as the case may be, the Purchaser after giving a reasonable opportunity of being heard, may take appropriate measures including –

- a) exclusion of the bidder from the procurement process;
- b) calling off of pre-contract negotiations and forfeiture or encashment of bid security;
- c) forfeiture or encashment of any other security or bond relating to procurement;
- d) recovery of payments made by the Purchaser along with interest thereon at bank rate;
- e) cancellation of the relevant contract and recovery of compensation for loss incurred by the Purchaser;
- f) debarment of the bidder from participation in any future procurements from Purchaser for a period not exceeding three years.

4. Interpretation

4.1 If the context so requires it, singular means plural and vice versa.

4.2 Incoterms

- a) Unless inconsistent with any provision of the Contract, the meaning of any trade term and the rights and obligations of parties thereunder shall be as prescribed by Incoterms.
- b) The term DDP and other similar terms, when used, shall be governed by the rules prescribed in the current edition of Incoterms **as specified in the SCC** and published by the International Chamber of Commerce in Paris, France.

4.3 Entire Agreement

The Contract constitutes the entire agreement between the Purchaser and the Supplier and supersedes all communications, negotiations and agreements (whether written or oral) of the parties with respect thereto made prior to the date of Contract.

4.4 Amendment

No amendment or other variation of the Contract shall be valid unless it is in writing, is dated, expressly refers to the Contract, and is signed by a duly authorized representative of each party thereto.

4.5 Non-waiver

- (a) Subject to GCC Sub-Clause 4.5(b) below, no relaxation, forbearance, delay, or indulgence by either party in enforcing any of the terms and conditions of the Contract or the granting of time by either party to the other shall prejudice, affect, or restrict the rights of that party under the Contract, neither shall any waiver by either party of any breach of Contract operate as waiver of any subsequent or continuing breach of Contract.
- (b) Any waiver of a party's rights, powers, or remedies under the Contract must be in writing, dated, and signed by an authorized representative of the party granting such waiver, and must specify the right and the extent to which it is being waived.

4.6 Severability

If any provision or condition of the Contract is prohibited or rendered invalid or unenforceable, such prohibition, invalidity or unenforceability shall not affect the validity or enforceability of any other provisions and conditions of the Contract.

5. Language

- 5.1 The Contract as well as all correspondence and documents relating to the Contract exchanged by the Supplier and the Purchaser, shall be written in English language. Supporting documents and printed literature that are part of the Contract may be in another language provided they are accompanied by a self-certified accurate translation of the relevant passages in English language, in which case, for purposes of interpretation of the Contract, this translation shall govern.
- 5.2 The Supplier shall bear all costs of translation to the governing language and all risks of the accuracy of such translation, for documents provided by the Supplier.

6. Joint Venture or Consortium

- 6.1 If the Supplier is a joint venture, or consortium, all of the parties shall be jointly and severally liable to the Purchaser for the fulfillment of the provisions of the Contract and shall designate one party to act as a leader with authority to bind the joint venture or consortium. The composition or the constitution of the joint venture or, consortium, shall not be altered without the prior consent of the Purchaser.

7. Eligibility

- 7.1 The Supplier and its Subcontractors shall have the nationality of any country with which India has not banned trade relations.

- 7.2 All Goods to be supplied under the contract shall have their origin in India or any other country with which India has not banned trade relations. The term “origin” used in this clause means the place where the goods are mined, grown, produced, or manufactured or from where the related services are arranged and supplied
- 8. Notices**
- 8.1 Any notice given by one party to the other pursuant to the Contract shall be in writing to the **address specified in the SCC**. The term “in writing” means communicated in written form with proof of receipt.
- 8.2 A notice shall be effective from the date of delivery or on the notice’s effective date, whichever is later. In case of electronic mode of communication, a notice shall be effective from the time of sending of the electronic communication.
- 9. Governing Law**
- 9.1 The Contract shall be governed by and interpreted in accordance with the laws of the Union of India.
- 10 Settlement of Disputes**
- 10.1 The Purchaser and the Supplier shall make every effort to resolve amicably any disagreement or dispute arising between them under or in connection with the Contract.
- 10.2 Dispute Redress mechanism/ Committees: 2-tier (Procuring entity level headed by the Director, State Redress Committee).
- 10.3 If, the dispute is not settled through dispute settlement mechanism and if after sixty (60) days, the parties have failed to resolve their dispute or difference by such mutual consultation, then either the Purchaser or the Supplier may give notice to the other party of its intention to commence arbitration wherever applicable, as hereinafter provided, as to the matter in dispute, and no arbitration in respect of this matter may be commenced unless such notice is given. Any dispute or difference in respect of which a notice of intention to commence arbitration has been given in accordance with this Clause shall be finally settled by arbitration. Arbitration may be commenced prior to or after delivery of the Goods under the Contract. Arbitration proceedings shall be conducted in accordance with the rules of procedure **specified in the SCC**.
- 10.4 Notwithstanding any reference to arbitration herein,
- (a) the parties shall continue to perform their respective obligations under the Contract unless they otherwise agree; and
- (b) the Purchaser shall not be required to pay the Supplier any monies to the Supplier in respect of the matter related to the arbitration unless otherwise agreed.
- 11. Inspections and Audit by the Purchaser**
- 11.1 The Supplier shall keep, and shall make all reasonable efforts to cause its Subcontractors to keep, accurate and systematic accounts and

records in respect of the Goods in such form and details as will clearly identify relevant time changes and costs.

11.2 The Supplier shall permit, and shall cause its Subcontractors to permit, the Purchaser and/or persons appointed by the Purchaser to inspect the Supplier's offices and all accounts and records relating to the performance of the Contract and the submission of the bid, and to have such accounts and records audited by auditors appointed by the Purchaser, if requested. The Supplier's and its Subcontractors and consultants' attention is drawn to Clause 3 [Code of Integrity], which provides, inter alia, that acts intended to materially impede the exercise of the Purchaser's inspection and audit rights provided for under this Sub-Clause 11.1 constitute a prohibited practice subject to contract termination (as well as to a determination of ineligibility pursuant to the Purchaser's prevailing sanctions procedures)

12. Scope of Supply

12.1 The Goods and Related Services to be supplied shall be as specified in the Schedule of Requirements.

13. Delivery and Documents

13.1 Subject to GCC Sub-Clause 33.1, the Delivery of the Goods and Completion of the Related Services shall be in accordance with the Delivery and Completion Schedule specified in the Schedule of Requirements. The details of shipping and other documents to be furnished by the Supplier are specified in the **SCC**.

14. Supplier's Responsibilities

14.1 The Supplier shall supply all the Goods and Related Services included in the Scope of Supply in accordance with GCC Clause 12, and the Delivery and Completion Schedule, as per GCC Clause 13.

15 Contract Price

15.1 Prices charged by the Supplier for the Goods supplied and the Related Services performed under the Contract shall not vary from the prices quoted by the Supplier in its bid, with the exception of any price adjustments authorized in the **SCC**.

16. Terms of Payment

16.1 The Contract Price, including any Advance Payments, if applicable, shall be paid as specified in the **SCC**.

16.2 The Supplier's request for payment shall be made to the Purchaser in writing, accompanied by invoices describing, as appropriate, the Goods delivered and related services performed, and by the documents submitted pursuant to GCC Clause 13 and upon fulfillment of all other obligations stipulated in the Contract.

16.3 Payments shall be made by the Purchaser, after submission of an invoice or request for payment by the Supplier, and after the Purchaser has accepted it subject to the defect liability as specified in the SCC.

16.4 The payments shall be made to the Supplier under this Contract in Indian Rupees only.

17. Taxes and Duties

17.1 The Supplier shall be entirely responsible for all taxes, duties, license fees, etc., incurred until delivery of the contracted Goods to the Purchaser.

18. Performance Security

18.1 If required as specified in the SCC, the Supplier shall, within fifteen (15) days of the notification of contract award, provide a performance security for the performance of the Contract in the amount specified in the **SCC**.

18.2 The proceeds of the Performance Security shall be payable to the Purchaser as compensation for any loss resulting from the Supplier's failure to complete its obligations under the Contract.

18.3 The Performance Security if required, shall be denominated in Indian Rupees and shall be in one of the format stipulated by the Purchaser in the **SCC**.

18.4 The Performance Security shall be discharged by the Purchaser and returned to the Supplier not later than twenty-eight (28) days following the date of Completion of the Supplier's performance obligations under the Contract, including any warranty obligations, unless specified otherwise in the **SCC**.

19. Copyright

19.1 The copyright in all drawings, documents, and other materials containing data and information furnished to the Purchaser by the Supplier herein shall remain vested in the Supplier, or, if they are furnished to the Purchaser directly or through the Supplier by any third party, including suppliers of materials, the copyright in such materials shall remain vested in such third party

20. Patent Indemnity

20.1 The Supplier shall, subject to the Purchaser's compliance with GCC Sub-Clause 20.2, indemnify and hold harmless the Purchaser and its employees and officers from and against any and all suits, actions or administrative proceedings, claims, demands, losses, damages, costs, and expenses of any nature, including attorney's fees and expenses, which the Purchaser may suffer as a result of any infringement or alleged infringement of any patent, utility model, registered design, trademark, copyright, or other intellectual property right registered or otherwise existing at the date of the Contract by reason of:

- (a) the installation of the Goods by the Supplier or the use of the Goods at the Purchaser's Site; and
- (b) the sale in any country of the products produced by the Goods.

Such indemnity shall not cover any use of the Goods or any part thereof other than for the purpose indicated by or to be reasonably inferred from the Contract, neither any infringement resulting from the use of the Goods or any part thereof, or any products produced thereby in association or combination with any other equipment,

plant, or materials not supplied by the Supplier, pursuant to the Contract.

- 20.2 If any proceedings are brought or any claim is made against the Purchaser arising out of the matters referred to in GCC Sub-Clause 20.1, the Purchaser shall promptly give the Supplier a notice thereof, and the Supplier may at its own expense and in the Purchaser's name conduct such proceedings or claim and any negotiations for the settlement of any such proceedings or claim.
- 20.3 If the Supplier fails to notify the Purchaser within twenty-eight (28) days after receipt of such notice that it intends to conduct any such proceedings or claim, then the Purchaser shall be free to conduct the same on its own behalf.
- 20.4 The Purchaser shall, at the Supplier's request, afford all available assistance to the Supplier in conducting such proceedings or claim, and shall be reimbursed by the Supplier for all reasonable expenses incurred in so doing.
- 20.5 The Purchaser shall indemnify and hold harmless the Supplier and its employees, officers, and Subcontractors from and against any and all suits, actions or administrative proceedings, claims, demands, losses, damages, costs, and expenses of any nature, including attorney's fees and expenses, which the Supplier may suffer as a result of any infringement or alleged infringement of any patent, utility model, registered design, trademark, copyright, or other intellectual property right registered or otherwise existing at the date of the Contract arising out of or in connection with any design, data, drawing, specification, or other documents or materials provided or designed by or on behalf of the Purchaser.

21. Confidential Information

- 21.1 The Purchaser and the Supplier shall keep confidential and shall not, without the written consent of the other party hereto, divulge to any third party any documents, data, or other information furnished directly or indirectly by the other party hereto in connection with the Contract, whether such information has been furnished prior to, during or following completion or termination of the Contract. Notwithstanding the above, the Supplier may furnish to its Subcontractor such documents, data, and other information it receives from the Purchaser to the extent required for the Subcontractor to perform its work under the Contract, in which event the Supplier shall obtain from such Subcontractor an undertaking of confidentiality similar to that imposed on the Supplier under GCC Clause 20.
- 21.2 The Purchaser shall not use such documents, data, and other information received from the Supplier for any purposes unrelated to the contract. Similarly, the Supplier shall not use such documents,

data, and other information received from the Purchaser for any purpose other than the performance of the Contract.

21.3 The obligation of a party under GCC Sub-Clauses 21.1 and 21.2 above, however, shall not apply to information that:

- (a) the Purchaser or Supplier need to share with the such institution(s) participating in the financing of the Contract;
- (b) now or hereafter enters the public domain through no fault of that party;
- (c) can be proven to have been possessed by that party at the time of disclosure and which was not previously obtained, directly or indirectly, from the other party; or
- (d) otherwise lawfully becomes available to that party from a third party that has no obligation of confidentiality.

21.4 The above provisions of GCC Clause 21 shall not in any way modify any undertaking of confidentiality given by either of the parties hereto prior to the date of the Contract in respect of the Supply or any part thereof.

21.5 The provisions of GCC Clause 21 shall survive completion or termination for whatever reason, of the Contract.

22. Subcontracting

22.1 The Supplier shall notify the Purchaser in writing of all subcontracts awarded under the Contract if not already specified in the bid. Such notification, in the original bid or later shall not relieve the Supplier from any of its obligations, duties, responsibilities, or liability under the Contract.

22.2 Subcontracts shall comply with the provisions of GCC Clauses 3 and 7.

23.

Specifications and Standards

23.1 Technical Specifications and Drawings

- (a) The Goods and Related Services supplied under this Contract shall conform to the technical specifications and standards mentioned in Section VI, Schedule of Requirements and, when no applicable standard is mentioned, the standard shall be equivalent or superior to the official standards whose application is appropriate to the Goods' country of origin.
- (b) The Supplier shall be entitled to disclaim responsibility for any design, data, drawing, specification or other document, or any modification thereof provided or designed by or on behalf of the Purchaser, by giving a notice of such disclaimer to the Purchaser.
- (c) Wherever references are made in the Contract to codes and standards in accordance with which it shall be executed, the edition or the revised version of such codes and standards shall be those specified in the Schedule of Requirements. During Contract execution, any changes in any such codes and standards shall be

applied only after approval by the Purchaser and shall be treated in accordance with GCC Clause 33.

24. Packing and Documents

- 24.1 The Supplier shall provide such packing of the Goods as is required to prevent their damage or deterioration during transit to their final destination, as indicated in the Contract. During transit, the packing shall be sufficient to withstand, without limitation, rough handling and exposure to extreme temperatures, salt and precipitation, and open storage. Packing case size and weights shall take into consideration, where appropriate, the remoteness of the goods' final destination and the absence of heavy handling facilities at all points in transit.
- 24.2 The packing, marking, and documentation within and outside the packages shall comply strictly with such special requirements as shall be expressly provided for in the Contract, including additional requirements, if any, specified in the **SCC**, and in any other instructions ordered by the Purchaser.

25. Insurance

- 25.1 Unless otherwise specified in the **SCC**, the Goods supplied under the Contract shall be fully insured against loss or damage incidental to manufacture or acquisition, transportation, storage, and delivery, in accordance with the applicable Incoterms or in the manner specified in the **SCC**.

26. Transportation and Incidental Services

- 26.1 Unless otherwise specified in the **SCC**, responsibility for arranging transportation of the Goods shall be in accordance with the specified Incoterms.
- 26.2 The Supplier may be required to provide any or all of the following services, including additional services, if any, **specified in SCC**:
- (a) performance or supervision of on-site assembly and/or start-up of the supplied Goods;
 - (b) furnishing of tools required for assembly and/or maintenance of the supplied Goods;
 - (c) furnishing of a detailed operations and maintenance manual for each appropriate unit of the supplied Goods;
 - (d) performance or supervision or maintenance and/or repair of the supplied Goods, for a period of time agreed by the parties, provided that this service shall not relieve the Supplier of any warranty obligations under this Contract; and
 - (e) training of the Purchaser's personnel, at the Supplier's plant and/or on-site, in assembly, start-up, operation, maintenance, and/or repair of the supplied Goods.
- 26.3 Prices charged by the Supplier for incidental services, if not included in the Contract Price for the Goods, shall be agreed upon in advance by the

parties and shall not exceed the prevailing rates charged to other parties by the Supplier for similar services

27. Inspections and Tests

- 27.1 The Supplier shall at its own expense and at no cost to the Purchaser carry out all such tests and/or inspections of the Goods as are specified in the **SCC**.
- 27.2 The inspections and tests may be conducted on the premises of the Supplier or its Subcontractor, at point of delivery, and/or at the Goods' final destination, or in another place in the Purchaser's Country as specified in the **SCC**. Subject to GCC Sub-Clause 27.3, if conducted on the premises of the Supplier or its Subcontractor, all reasonable facilities and assistance including access to drawings and production data, shall be furnished to the inspectors at no charge to the Purchaser.
- 27.3 The Purchaser or its designated representative shall be entitled to attend the tests and/or inspections referred to in GCC Sub-Clause 27.2, provided that the Purchaser bear all of its own costs and expenses incurred in connection with such attendance including, but not limited to, all traveling and board and lodging expenses.
- 27.4 Whenever the Supplier is ready to carry out any such test and inspection, it shall give a reasonable advance notice, including the place and time, to the Purchaser. The Supplier shall obtain from any relevant third party or manufacturer any necessary permission or consent to enable the Purchaser or its designated representative to attend the test and/or inspection.
- 27.5 The Supplier shall provide the Purchaser with a report of the results of any such test and/or inspection.
- 27.6 The Purchaser may reject any Goods or any part thereof that fail to pass any test and/or inspection or do not conform to the specifications. The Supplier shall either rectify or replace such rejected Goods or parts thereof or make alterations necessary to meet the specifications at no cost to the Purchaser, and shall repeat the test and/or inspection, at no cost to the Purchaser, upon giving a notice pursuant to GCC Sub-Clause 27.4.
- 27.7 The Supplier agrees that neither the execution of a test and/or inspection of the Goods or any part thereof, nor the attendance by the Purchaser or its representative, nor the issue of any report pursuant to GCC Sub-Clause 27.5, shall release the Supplier from any warranties or other obligations under the Contract.

28. Liquidated Damages

- 28.1 Except as provided under GCC Clause 32, if the Supplier fails to deliver any or all of the Goods by the Date(s) of delivery or perform the Related Services within the period specified in the Contract, the Purchaser may without prejudice to all its other remedies under the Contract, deduct from the Contract Price, as liquidated damages, a sum equivalent to the percentage specified in the **SCC** of the delivered price of the delayed Goods or unperformed Services for each week or

part thereof of delay until actual delivery or performance, up to a maximum deduction of the percentage specified in the **SCC**. Once the maximum is reached, the Purchaser may terminate the Contract pursuant to GCC Clause 35.

29. Warranty

- 29.1 The Supplier warrants that all the Goods are new, unused, and of the most recent or current models, and that they incorporate all recent improvements in design and materials, unless provided otherwise in the Contract.
- 29.2 Subject to GCC Sub-Clause 23.1(b), the Supplier further warrants that the Goods shall be free from defects arising from any act or omission of the Supplier or arising from design, materials, and workmanship, under normal use in the conditions prevailing in the state.
- 29.3 Unless otherwise specified in the **SCC**, the warranty shall remain valid for twelve (12) months after the Goods, or any portion thereof, as the case may be, have been delivered to and accepted at the final destination indicated in the **SCC**.
- 29.4 The Purchaser shall give notice to the Supplier stating the nature of any such defects together with all available evidence thereof, promptly following the discovery thereof. The Purchaser shall afford all reasonable opportunity for the Supplier to inspect such defects.
- 29.5 Upon receipt of such notice, the Supplier shall, within the period specified in the **SCC**, expeditiously repair or replace the defective Goods or parts thereof, at no cost to the Purchaser.
- 29.6 If having been notified, the Supplier fails to remedy the defect within the period specified in the **SCC**, the Purchaser may proceed to take within a reasonable period such remedial action as may be necessary, at the Supplier's risk and expense and without prejudice to any other rights which the Purchaser may have against the Supplier under the Contract.

30 Limitation of Liability

- 30.1 Except in cases of criminal negligence or willful misconduct, the aggregate liability of the Supplier to the Purchaser, whether under the Contract, in tort or otherwise, shall not exceed the total Contract Price, provided that this limitation shall not apply to the cost of repairing or replacing defective equipment, or to any obligation of the supplier to indemnify the purchaser with respect to patent infringement.

31. Change in Laws and Regulations

- 31.1 Unless otherwise specified in the Contract, if after the date of 28 days prior to date of Bid submission, any law, regulation, ordinance, order or bylaw having the force of law is enacted, promulgated, abrogated, or changed in India (which shall be deemed to include any change in interpretation or application by the competent authorities) that subsequently affects the Delivery Date and/or the Contract Price, then such Delivery Date and/or Contract Price shall be correspondingly increased or decreased, to the extent that the Supplier has thereby

been affected in the performance of any of its obligations under the Contract. Notwithstanding the foregoing, such additional or reduced cost shall not be separately paid or credited if the same has already been accounted for in the price adjustment provisions where applicable, in accordance with GCC Clause 15.

32. Force Majeure

- 32.1 The Supplier shall not be liable for forfeiture of its Performance Security, liquidated damages, or termination for default if and to the extent that its delay in performance or other failure to perform its obligations under the Contract is the result of an event of Force Majeure.
- 32.2 For purposes of this Clause, "Force Majeure" means an event or situation beyond the control of the Supplier that is not foreseeable, is unavoidable, and its origin is not due to negligence or lack of care on the part of the Supplier. Such events may include, but not be limited to, acts of the Purchaser in its sovereign capacity, wars or revolutions, fires, floods, epidemics, quarantine restrictions, and freight embargoes.
- 32.3 If a Force Majeure situation arises, the Supplier shall promptly notify the Purchaser in writing of such condition and the cause thereof. Unless otherwise directed by the Purchaser in writing, the Supplier shall continue to perform its obligations under the Contract as far as is reasonably practical, and shall seek all reasonable alternative means for performance not prevented by the Force Majeure event.

33. Change Orders and Contract Amendments

- 33.1 The Purchaser may at any time order the Supplier through notice in accordance to GCC Clause 8, to make changes within the general scope of the Contract in any one or more of the following:
- (a) drawings, designs, or specifications, where Goods to be furnished under the Contract are to be specifically manufactured for the Purchaser;
 - (b) the method of shipment or packing;
 - (c) the place of delivery; and
 - (d) the related services to be provided by the Supplier.
- 33.2 If any such change causes an increase or decrease in the cost of, or the time required for the Supplier's performance of any provisions under the Contract, an equitable adjustment shall be made in the Contract Price or in the Delivery/Completion Schedule, or both, and the Contract shall accordingly be amended. Any claims by the Supplier for adjustment under this Clause must be asserted within twenty-eight (28) days from the date of the Supplier's receipt of the Purchaser's change order.
- 33.3 Prices to be charged by the Supplier for any related services that might be needed but which were not included in the Contract shall be agreed upon in advance by the parties and shall not exceed the

prevailing rates charged to other parties by the Supplier for similar services.

33.4 Subject to the above, no variation in or modification of the terms of the Contract shall be made except by written amendment signed by the parties.

34. Extensions of Time

34.1 If at any time during performance of the Contract, the Supplier or its subcontractors should encounter conditions impeding timely delivery of the Goods or completion of related services pursuant to GCC Clause 14, the Supplier shall promptly notify the Purchaser in writing of the delay, its likely duration, and its cause. As soon as practicable after receipt of the Supplier's notice, the Purchaser shall evaluate the situation and may at its discretion extend the Supplier's time for performance, in which case the extension shall be ratified by the parties by amendment of the Contract.

34.2 Except in case of Force Majeure, as provided under GCC Clause 32, a delay by the Supplier in the performance of its Delivery and Completion obligations shall render the Supplier liable to the imposition of liquidated damages pursuant to GCC Clause 28, unless an extension of time is agreed upon, pursuant to GCC Sub-Clause 34.1.

35. Termination

35.1 Termination for Default

(a) The Purchaser, without prejudice to any other remedy for breach of Contract, by written notice of default sent to the Supplier, may terminate the Contract in whole or in part:

- i) if the Supplier fails to deliver any or all of the Goods within the period specified in the Contract, or within any extension thereof granted by the Purchaser pursuant to GCC Clause 34;
- ii) if the Supplier fails to perform any other obligation under the Contract; or
- iii) if the Supplier, in the judgment of the Purchaser has engaged in breach of Code of Integrity, as defined in GCC Clause 3, in competing for or in executing the Contract.

(b) In the event the Purchaser terminates the Contract in whole or in part, pursuant to GCC Clause 35.1(a), the Purchaser may procure, upon such terms and in such manner as it deems appropriate, Goods similar to those undelivered or not performed, and the Supplier shall be liable to the Purchaser for any additional costs for such similar Goods procured by the Purchaser.. However, the Supplier shall continue performance of the Contract to the extent not terminated.

35.2 Termination for Insolvency.

The Purchaser may at any time terminate the Contract by giving notice to the Supplier if the Supplier becomes bankrupt or otherwise insolvent. In

such event, termination will be without compensation to the Supplier, provided that such termination will not prejudice or affect any right of action or remedy that has accrued or will accrue thereafter to the Purchaser

35.3 Termination for Convenience.

The Purchaser, by notice sent to the Supplier, may terminate the Contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that termination is for the Purchaser's convenience, the extent to which performance of the Supplier under the Contract is terminated, and the date upon which such termination becomes effective.

The Goods that are complete and ready for shipment within twenty-eight (28) days after the Supplier's receipt of notice of termination shall be accepted by the Purchaser at the Contract terms and prices. For the remaining Goods, the Purchaser may elect:

to have any portion completed and delivered at the Contract terms and prices; and/or

to cancel the remainder and pay to the Supplier an agreed amount for partially completed Goods and for materials and parts previously procured by the Supplier.

36. Assignment

36.1 Neither the Purchaser nor the Supplier shall assign, in whole or in part, their obligations under this Contract, except with prior written consent of the other party.

Section VIII – Special Conditions of Contract

The following Special Conditions of Contract (SCC) shall supplement and / or amend the General Conditions of Contract (GCC). Whenever there is a conflict, the provisions herein shall prevail over those in the GCC

GCC 1.1(h)	The Purchaser is: _____
GCC 1.1 (l)	The Project Site(s)/Final Destination(s) is Specified in Schedule of Requirement.
GCC 4.2 (b)	The version edition of Incoterms shall be <i>2020</i>
GCC 8.1	For <u>notices</u> , the Purchaser’s address shall be: _____ For <u>notices</u> , the Supplier’s address shall be: _____
GCC 10.3	<p>The rules of procedure for arbitration proceedings pursuant to GCC Clause 10.3 shall be as follows:</p> <p>i) In case of Dispute or difference arising between the Purchaser and a supplier relating to any matter arising out of or connected with this agreement, such disputes or difference shall be settled in accordance with the Arbitration and Conciliation Act, 1996. The arbitral tribunal shall consist of 3 arbitrators one each to be appointed by the Purchaser and the Supplier. The third Arbitrator shall be chosen by the two Arbitrators so appointed by the Parties and shall act as Presiding arbitrator. In case of failure of the two arbitrators appointed by the parties to reach upon a consensus within a period of 30 days from the appointment of the arbitrator appointed subsequently, the Presiding Arbitrator shall be appointed in accordance with the provisions of the Arbitration and Conciliation Act 1996.</p> <p>ii) If one of the parties fails to appoint its arbitrator in pursuance of sub clause (a) above, within 30 days after receipt of the notice of the appointment of its arbitrator by the other party, then the appointment of the Arbitrator shall be made in accordance with the provisions of the Arbitration and Conciliation Act 1996.</p> <p>iii) The venue of Arbitration shall be New Delhi and the language of the arbitration proceedings and that of all councils and communications between the parties shall be English.</p> <p>iv) The decision of the majority of arbitrators shall be final and binding upon parties. The cost and expenses of Arbitration proceedings will be paid as</p>

	<p>determined by the arbitral tribunal. However, the expenses incurred by each party in connection with the preparation, presentation, etc. of its proceedings as also the fees and expenses paid to the arbitrator appointed by such party or on its behalf shall be borne by each party itself.</p> <p>v) The provisions of the Arbitration and Conciliation Act of 1996 along with the Rules herewith and any statutory modification or reenactment thereof shall apply to arbitration proceedings.</p> <p>vi) If a dispute under the Supplier Contract raises the same issues as those in respect of a related dispute with another supplier contract, the Purchaser will have the option of having the arbitration proceedings joined.</p>
<p>GCC 12 (additional clause 12.2)</p>	<p>Add as a new Clause 12.2 of the GCC</p> <p><i>[in case annual maintenance services are required post warranty, add these clauses with modifications as appropriate]</i></p> <p>The supplier will provide 2 years warranty that will include Comprehensive Annual maintenance (Contract) including all spare parts and repair <i>[insert as required]</i></p> <p>The supplier shall visit each site at least twice a year for preventive maintenance of equipment. During such visits, shall provide operational training to concerned staff on use of equipment. The Schedule of such visits should be shared with consignee in advance. The manufacturer should be able to provide service of equipment across the State within 24- 48 hours after receipt of breakdown report for the metro location and within 3-5 days for the non-metro located instruments, failing which a penalty as stipulated below will apply</p> <p>During the Warranty period in case of non-compliance of the above, liquidated damages at the rate of 0.075% of the Contract Price per non-functional unit per day, beyond timeline given above (for metro and non-metro located instruments) shall be imposed and equivalent amount shall be deducted from the performance security</p>
<p>GCC 13.1</p>	<p>Details of Documents to be furnished by the Supplier are:</p> <ul style="list-style-type: none"> (i) One original and two copies of the supplier’s commercial invoice in name of Purchaser, indicating the Contract number, Goods description, quantity, unit price, and total amount being claimed. Invoices must be signed in original and stamped, or sealed with the company stamp/seal; (ii) Two copies of the packing list identifying contents of each package (iii) One original of the manufacturer’s Warranty Certificate covering all items supplied; (iv) Original and two copies of Certificate of Inspection furnished to supplier by the nominated agency (where inspection is required);

	<p>(v) Original and two copies of Internal Test Analysis Report of the Manufacturer for the items offered</p> <p>(vi) Original of supplier's Certificate of Origin covering all items supplied;</p> <p>(vii) Any other/additional procurement-specific documents required for delivery/payment purposes showing delivery up to final destination.</p>
GCC 15.1	The prices charged for the Goods supplied and the related Services performed shall be fixed during the performance of the contract.
GCC 16.1	<p>The payment under this Contract shall be released by the Purchaser after due scrutiny, verification of documents submitted by supplier. Payment shall be made by Electronic clearing systems (ECS) to the Supplier's nominated bank account. The method and conditions of payment to be made to the Supplier shall be as follows:</p> <p><i>[the clauses below are suggestive; the purchaser may modify as appropriate]</i></p> <p>(a) On Delivery: Ninety (90) percent of the Contract Price of the Goods delivered to the consignee shall be paid within sixty (60) days of submission of documents specified in SCC Clause 13 above and Consignee Receipt Certificate</p> <p>(b) On Successful, Installation, Commissioning and Testing of equipment: Ten (10) percent of the Contract Price of Goods received shall be paid within sixty (60) days of receipt of Final Acceptance Certificate issued by the consignee.</p>
GCC 18.1	<p>Within 15 days after the Supplier's receipt of Notification of Award, the Supplier shall furnish Performance Security to the Purchaser for an amount of 3% <i>[insert as appropriate]</i> of the contract value, valid up to 90 days after the date of completion of performance obligations including warranty obligations.</p> <p>In the event of any correction of defects or replacement of defective material during the warranty period, the warranty for the corrected/replaced material shall be extended to a further period of 12 months and the Performance Bank Guarantee for proportionate value shall be extended 90 days over and above the extended warranty period.</p>
GCC 18.3	The performance security shall be in the form of a bank guarantee and the named beneficiary shall be _____ [name of purchaser] . The bank guarantee shall be issued by a Scheduled Bank in India and in the format provided in the Bidding Documents.
GCC 18.4	The Performance Security will be discharged and returned to the Supplier not later than 60 days following the date of completion of the Supplier's performance obligations, including any warranty obligation, under the contract.

GCC 24.2	<p>The packing, marking and documentation within and outside the packages shall be</p> <p><u>Packing Instructions</u>: The Supplier will be required to make separate packages for each Consignee. Each package will be marked with proper paint/indelible ink with the following: <i>[insert as required]</i></p>
GCC 25.1	<p>The insurance shall be in an amount equal to 110 percent of the CIP value of the Goods from “warehouse” to “warehouse” on “All Risks” basis, including war risks and strikes showing purchaser as Beneficiary.</p>
GCC 26.1	<p>The Supplier is required under the Contract to transport the Goods to the specified place of final destination. Transportation to such place of destination, including unloading, insurance and storage, as shall be specified in the Contract, shall be arranged by the Supplier, and related costs are included in the Contract Price.</p>
GCC 26.2	<p>Incidental services to be provided are: As per Section – V Schedule of Requirement – Technical Specifications</p>
GCC 27.1	<p>The Supplier shall conduct tests to confirm that the goods supplied are as per specification and enclose the test and inspection certificate along with supply.</p>
GCC 27.2	<p>The Purchaser or his representative may conduct the Inspections of the facility any time before the award of contract and also conduct Inspection for the Goods any time before or after the dispatch of Goods.</p> <p>Unless the Goods supplied according to the Schedule of Requirements is satisfactorily installed and training on use of the equipment is provided, the Consignee will not issue the Final Acceptance Certificate.</p>
GCC 28.1	<p>Applicable rate shall not exceed one-half percent (0.5%) per week or part thereof</p>
GCC 28.1	<p>The maximum amount of liquidated damages shall be: 10%</p>
GCC 29.3	<p>(i) In partial modification of the provisions, the warranty period shall remain valid for the period specified in Schedule of Requirements</p> <p>For purposes of the Warranty, the place(s) of final destination(s) shall be: as specified in the schedule of requirement</p> <p>The consignees mentioned in the Schedule of Requirement (Section V)</p>

GCC 29.5	<p>The manufacturer should be able to provide service of equipment across the State within 24- 48 hours after receipt of breakdown report for the metro location and within 3-5 days for the non-metro located instruments, failing which a penalty as stipulated below will apply.</p> <p>In the event of any correction of defects or replacement of defective material during the warranty period, the warranty for the corrected/replaced material shall be extended to a further period of 12 months." <i>[modify period as appropriate]</i></p>
-----------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Section – IX Contract Form

Contract Agreement

[The successful Bidder shall fill in this form in accordance with the instructions indicated]

THIS AGREEMENT made

the *[insert: number]* day of *[insert: month]*, *[insert: year]*.

BETWEEN

- (1) *[insert complete name of Purchaser]*, a *[insert description of type of legal entity, for example, an agency of the Ministry of of the Government of {insert name of Country of Purchaser}, or corporation incorporated under the laws of {insert name of Country of Purchaser}]* and having its principal place of business at *[insert address of Purchaser]* (hereinafter called “the Purchaser”), of the one part, and
- (2) *[insert name of Supplier]*, a corporation incorporated under the laws of *[insert: country of Supplier]* and having its principal place of business at *[insert: address of Supplier]* (hereinafter called “the Supplier”), of the other part :

WHEREAS the Purchaser invited bids for certain Goods and ancillary services, viz., *[insert brief description of Goods and Services]* and has accepted a Bid by the Supplier for the supply of those Goods and Services

The Purchaser and the Supplier agree as follows:

1. In this Agreement words and expressions shall have the same meanings as are respectively assigned to them in the Contract documents referred to.
2. The following documents shall be deemed to form and be read and construed as part of this Agreement. This Agreement shall prevail over all other contract documents.
 - (a) the Letter of Acceptance
 - (b) the Letter of Technical Bid and Financial Bid
 - (c) the Addenda Nos. _____ (if any)
 - (d) Special Conditions of Contract
 - (e) General Conditions of Contract
 - (f) the Specification (including Schedule of Requirements and Technical Specifications)
 - (g) the completed Schedules (including Price Schedule)
 - (h) any other document listed in GCC as forming part of the Contract

3. In consideration of the payments to be made by the Purchaser to the Supplier as specified in this Agreement, the Supplier hereby covenants with the Purchaser to provide the Goods and Services and to remedy defects therein in conformity in all respects with the provisions of the Contract.
4. The Purchaser hereby covenants to pay the Supplier in consideration of the provision of the Goods and Services and the remedying of defects therein, the Contract Price or such other sum as may become payable under the provisions of the Contract at the times and in the manner prescribed by the Contract.

IN WITNESS whereof the parties hereto have caused this Agreement to be executed in accordance with the laws of Union of India on the day, month and year indicated above.

For and on behalf of the Purchaser

Signed: *[insert signature]*

in the capacity of *[insert title or other appropriate designation]*

in the presence of *[insert identification of official witness]*

For and on behalf of the Supplier

Signed: *[insert signature of authorized representative(s) of the Supplier]*

in the capacity of *[insert title or other appropriate designation]*

in the presence of *[insert identification of official witness]*

Letter of Acceptance

[on letterhead paper of the Purchaser]

..... **date.**

To: *[insert name and address of the Supplier]*

Subject: **Contract No.**

This is to notify you that your Bid dated _____ *[insert **date of bid submitted by the bidder]*** for the execution of _____ *[insert **brief description of Goods and related services]*** against Bid Invitation Ref. No. _____ *(insert **Bid Ref. No.**)* is hereby accepted by the Purchaser for the Contract Amount of Rs. _____ *[insert **amount in numbers and words]***, as corrected and modified in accordance with the Instructions to Bidders.

You are requested to furnish the Performance Security within 28 days in accordance with the Conditions of Contract, using for that purpose the *of* the Performance Security Form included in Section IX, Contract Forms of the Bidding Documents.

Authorized Signature:

Name and Designation of Signatory:

Name of Purchaser:

Performance Security

Bank Guarantee

[The bank, as requested by the successful Bidder, shall fill in this form in accordance with the instructions indicated]

Beneficiary: *[insert name and Address of Purchaser]*

Date: *_ [Insert date of issue]*

PERFORMANCE GUARANTEE No.: *[Insert guarantee reference number]*

Guarantor: *[Insert name and address of place of issue, unless indicated in the letterhead]*

We have been informed that *_ [insert name of Supplier]* (hereinafter called "the Applicant") has entered into Contract No. *[insert reference number of the contract]* dated *[insert date]* with the Beneficiary, for the supply of *_ [insert name of contract and brief description of Goods and related Services]* (hereinafter called "the Contract").

Furthermore, we understand that, according to the conditions of the Contract, a performance guarantee is required.

At the request of the Applicant, we as Guarantor, hereby irrevocably undertake to pay the Beneficiary any sum or sums not exceeding in total an amount of *[insert amount in figures]* (*[insert amount in words]*),¹ such sum being payable in the types and proportions of currencies in which the Contract Price is payable, upon receipt by us of the Beneficiary's complying demand supported by the Beneficiary's statement, whether in the demand itself or in a separate signed document accompanying or identifying the demand, stating that the Applicant is in breach of its obligation(s) under the Contract, without the Beneficiary needing to prove or to show grounds for your demand or the sum specified therein.

This guarantee shall expire, no later than the Day of, 2...², and any demand for payment under it must be received by us at this office indicated above on or before that date.

[signature(s)]

¹ *The Guarantor shall insert an amount representing the percentage of the Accepted Contract Amount specified in the Letter of Acceptance.*

² *Insert the date twenty-eight days after the expected completion dates described in GC Clause 18.4. The Purchaser should note that in the event of an extension of this date for completion of the Contract, the Purchaser would need to request an extension of this guarantee from the Guarantor. Such request must be in writing and must be made prior to the expiration date established in the guarantee. In preparing this guarantee, the Purchaser might consider adding the following text to the form, at the end of the penultimate paragraph: "The Guarantor agrees to a one-time extension of this guarantee for a period not to exceed [six months][one year], in response to the Beneficiary's written request for such extension, such request to be presented to the Guarantor before the expiry of the guarantee."*

Note: All italicized text (including footnotes) is for use in preparing this form and shall be deleted from the final product.

Acknowledgement of Receipt of Goods (for 90% Payment)

(This certificate is to be issued to SAMS and copy to Supplier and FIND. All the three copies should be signed in ORIGINAL.)

CONSIGNEE RECEIPT CERTIFICATE (CRC)

CRC No.

Date

To
Strategic Alliance Management Services Pvt. Ltd,
B-18, Sector-06, NOIDA
Gautam Budh Nagar (U.P.)- 201301

This is to certify that the Goods as detailed below have been received with out any physical damage.

Project Name	Procurement Services to Foundation for Innovative New Diagnostics India (FIND India)
Purchaser	Strategic Alliance Management Services Pvt. Ltd., on behalf of FIND India
Contract i.e. NOA No. & Date	
Description of Goods Supplied Name of Equipment/ Laboratory Materials: Schedule No. as per Contract: Model: Serial No.:	
Packing and labeling details	
Date of manufacturing	
Date of Expiry	
Quantity supplied in Numbers	
Name of Supplier	
Invoice No. and Date	
Date of Delivery at Consignee Destination site	
Consignee full Address Name Address Contact No. Fax No.	

Seal Signature of Designated Consignee

Name :

Designation:

Seal:

Contact No:

Fax No. :

Copy To: (with Original Stamp and signature)

1. To Supplier
2. Procurement Officer, Foundation for Innovative New Diagnostics (FIND), Flat No. 6 & 8 – 14, 9th Floor, Vijaya Bank Building, 17, Barakhamba Road, New Delhi -110001, India

Final Acceptance Certificate (for Balance 10% Payment)
(This certificate is to be issued to SAMS and copy to Supplier. All the three copies 'should be signed in ORIGINAL'.)

FINAL ACCEPTANCE CERTIFICATE (FAC)

FAC No.

Date:

To

Strategic Alliance Management Services Pvt. Ltd,
 B-18, Sector-06, NOIDA
 Gautam Budh Nagar (U.P.)- 201301

Project Name	Procurement Services to Foundation for Innovative New Diagnostics India (FIND India)
Purchaser	Strategic Alliance Management Services Pvt. Ltd., on behalf of FIND India
Contract i.e. Notification of Award No. & Date	
Description of Goods Supplied Name of Equipment: Schedule No. as per Contract: Model: Serial No.:	
Name of Supplier	
Quantity Supplied in Numbers	
List with name of all or any accessories as per contract supplied with the equipment	
Date of Installation, testing and commissioning	
Is successful Installation, testing and commissioning of equipment supplied, upto the satisfaction of User done or not (Yes/No)	
Whether training provided to all users upto the satisfaction or not (Yes/No)	
Date of Final Acceptance	
Invoice No. and Date	
Date of entry in Asset register	
Consignee full Address Name Address Contact No.	

CERTIFICATE

This is to certify that we have received medical Equipment/ lab materials as detailed above in good condition in accordance with the Technical specifications and conditions of the NOA/ Contract and the same has been successfully Installed and Commissioned (if, applicable) on _____ to the satisfaction of all users and entered in the Asset/Consumable/Non-Consumable Register at page no. _____ on _____

**Seal & Signature of Designated
 Consignee
 Name:
 Designation:**

Copy To: (with Original Stamp and signature)

- (1) To Supplier
- (2) Procurement Officer, Foundation for Innovative New Diagnostics (FIND), Flat No. 6 & 8 – 14, 9th Floor, Vijaya Bank Building, 17, Barakhamba Road, New Delhi -110001, India