

Amendment No.2

Advertised Tender Enquiry (ATE) for Supply, Installation, Testing and Commissioning of Silent Diesel Generator (DG) Set and Servo Controlled Automatic Voltage Stabilizer across TB Labs under the National Tuberculosis Program (NTEP), Central TB Division (CTD), Govt of India

(Bid Ref No.: SAMS/FIND India/Proc./Equipment/ATE/04/2022 dt. 22/10/2022)

Responses regarding queries/suggestions received against the above tender:-

Sl. No.	Para / Clause Reference in Bid Document/ Page No.	Content of Para / Clause under Reference as per Bid Document	Query / Suggestions	Response / Amendments (Amendment No.2)*
1.	Section V; Schedule of Requirements; 3. Technical Specifications; Sch. 1 Diesel Generator Set Specifications; Page No. 35	-	<p>As per the DG set technical specification (page no 35) two panels are required. 1) Microprocessor based panel is required inside the canopy, 2) AMF panel needs to install outside the canopy, nearer to the existing LT distribution panel.</p> <p>However, the bidder can provide both the panels inside the DG set canopy with one manual change over switch outside of DG set for user operation having option of AMF mode and bypass mode and all required accessories cost need to be included in the site wise BOQ</p>	<p>As per the DG set technical specification (page no 35) two panels are required. 1) Microprocessor based panel is required inside the canopy, 2) AMF panel needs to install outside the canopy, nearer to the existing LT distribution panel.</p> <p>However, the bidder can provide one single panel inside the DG set canopy having all the required safety features, alarms and indications as mentioned in the technical specification of bid document with one manual change over switch outside of DG set for user operation having option of AMF mode and bypass mode with required control circuits and all required accessories cost need to be included in the site wise BOQ.</p>
2.	Form FIN 3 Cost of Works for all Schedules	-	<p>In technical Specification clause No. 6- you are asking for supplying and laying of 12 core 2.5sqmm armoured copper control cable it may be a typographical mistake, normally we provide 2 core cable. you are requested to kindly make the amendment for 12 cores to 2 cores.</p>	<p>As per BOQ we have asked "Supplying & Laying of 12 Core 2.5 Sqmm armoured copper control cable or as recommended by the company for connecting AMF Panel and Generator". so, the bidders are allowed to quote as per their compatibility between panel and generator. you can respond to them.</p>

**the bold contents are the amendments (Amendment no. 2) against the respective paras of Bid Document. The referred amendments shall be applicable to all relevant Sections of the Bid.*



Dinesh Kumar
Manager (Procurement), SAMS